Iowa Department of Natural Resources Title V Operating Permit

Name of Permitted Facility: IPL-Centerville Combustion Turbines and Diesels Station

Facility Location: 1625 North 14th Street, Centerville, Iowa Air Quality Operating Permit Number: 02-TV-023R3

Expiration Date: 4/10/2022

Permit Renewal Application Deadline: 10/10/2021

EIQ Number: 92-4971

Facility File Number: 04-01-003

Responsible Official

Name: Matt Hanson Title: Plant Manager

Mailing Address: 20775 Power Plant Road, Ottumwa, IA 52501

Phone #: (319) 786-2903

Permit Contact Person for the Facility

Name: Matt Hanson Title: Plant Manager

Mailing Address: 20775 Power Plant Road, Ottumwa, IA 52501

Phone #: (319) 786-2903

This permit is issued in accordance with 567 Iowa Administrative Code Chapter 22, and is issued subject to the terms and conditions contained in this permit.

For the Director of the Department of Natural Resources

Lori Hanson, Supervisor of Air Operating Permits Section

Date

Table of Contents

I.	Facility Description and Equipment List4
II.	Plant - Wide Conditions5
III.	Emission Point Specific Conditions7
IV.	General Conditions38
	G1. Duty to Comply
	G2. Permit Expiration
	G3. Certification Requirement for Title V Related Documents
	G4. Annual Compliance Certification
	G5. Semi-Annual Monitoring Report
	G6. Annual Fee
	G7. Inspection of Premises, Records, Equipment, Methods and Discharges
	G8. Duty to Provide Information
	G9. General Maintenance and Repair Duties
	G10. Recordkeeping Requirements for Compliance Monitoring
	G11. Evidence used in establishing that a violation has or is occurring.
	G12. Prevention of Accidental Release: Risk Management Plan Notification and Compliance Certification
	G13. Hazardous Release
	G14. Excess Emissions and Excess Emissions Reporting Requirements
	G15. Permit Deviation Reporting Requirements
	G16. Notification Requirements for Sources That Become Subject to NSPS and NESHAP
	Regulations
	G17. Requirements for Making Changes to Emission Sources That Do Not Require Title V
	Permit Modification
	G18. Duty to Modify a Title V Permit
	G19. Duty to Obtain Construction Permits
	G20. Asbestos
	G21. Open Burning
	G22. Acid Rain (Title IV) Emissions Allowances
	G23. Stratospheric Ozone and Climate Protection (Title VI) Requirements
	G24. Permit Reopenings
	G25. Permit Shield
	G26. Severability
	G27. Property Rights
	G28. Transferability
	G29. Disclaimer
	G30. Notification and Reporting Requirements for Stack Tests or Monitor Certification
	G31. Prevention of Air Pollution Emergency Episodes
	G32. Contacts List

V. Appendix(ices): Federal Rule Web links and Cross-State Air Pollution Rule (CSAPR) a.k.a Transport Rule (TR) Trading Program48 **Abbreviations** acfm.....actual cubic feet per minute CFRCode of Federal Regulation CEcontrol equipment CEM.....continuous emission monitor °F.....degrees Fahrenheit EIQ.....emissions inventory questionnaire EP.....emission point EUemission unit gr./dscfgrains per dry standard cubic foot IAC.....Iowa Administrative Code IDNR.....Iowa Department of Natural Resources MVAC.....motor vehicle air conditioner NAICS......North American Industry Classification System NSPSnew source performance standard ppmvparts per million by volume lb./hr....pounds per hour lb./MMBtupounds per million British thermal units SCC.....Source Classification Codes scfm.....standard cubic feet per minute SIC..... Standard Industrial Classification TPYtons per year USEPA.....United States Environmental Protection Agency **Pollutants** PM.....particulate matter PM₁₀particulate matter ten microns or less in diameter SO₂sulfur dioxide

NO_xnitrogen oxides

CO.....carbon monoxide
HAP....hazardous air pollutant

VOC..... volatile organic compound

I. Facility Description and Equipment List

Facility Name: IPL-Centerville Combustion Turbines and Diesels Station Permit Number: 02-TV-023R3

Facility Description: Electric Services (SIC 4911)

Equipment List

Emission Point Number	Emission Unit Number	Emission Unit Description	DNR Construction Permit Number
EP-1	EU-1	Combustion Turbine #1	89-A-141-S2
EP-4	EU-2	Startup Engine #1	98-A-097-S1
EP-6	EU-6	Combustion Turbine #2	98-A-096-S1
EP-9	EU-7	Startup Engine #2	98-A-098-S1
EP-11	EU-11	Storage Tank	01-A-888
EP-14	EU-14	Diesel Generator #1	98-A-099-S1
EP-15	EU-15	Diesel Generator #2	98-A-100-S1
EP-16	EU-16	Diesel Generator #3	98-A-101-S1

Insignificant Activities Equipment List

Insignificant Emission Unit	Insignificant Emission Unit Description
Number	
IU-2	2 Roof Vents
IU-3	Turbine Lube Oil Vent
IU-7	2 Roof Vents
IU-8	Turbine Lube Oil Vent
IU-9	Turbine Day Tank (120 gal)
IU-10	Turbine Day Tank (120 gal)

II. Plant-Wide Conditions

Facility Name: IPL-Centerville Combustion Turbines and Diesels Station

Permit Number: 02-TV-023R3

Permit conditions are established in accord with 567 Iowa Administrative Code rule 22.108

Permit Duration

The term of this permit is: 5 Years

Commencing on: 4/11/2017 Ending on: 4/10/2022

Amendments, modifications and reopenings of the permit shall be obtained in accordance with 567 Iowa Administrative Code rules 22.110 - 22.114. Permits may be suspended, terminated, or revoked as specified in 567 Iowa Administrative Code Rules 22.115.

Emission Limits

Unless specified otherwise in the Source Specific Conditions, the following limitations and supporting regulations apply to all emission points at this plant:

Opacity (visible emissions): 40% opacity

Authority for Requirement: 567 IAC 23.3(2)"d"

Sulfur Dioxide (SO₂): 500 parts per million by volume

Authority for Requirement: 567 IAC 23.3(3)"e"

Particulate Matter:

No person shall cause or allow the emission of particulate matter from any source in excess of the emission standards specified in this chapter, except as provided in 567 – Chapter 24. For sources constructed, modified or reconstructed after July 21, 1999, the emission of particulate matter from any process shall not exceed an emission standard of 0.1 grain per dry standard cubic foot of exhaust gas, except as provided in 567 – 21.2(455B), 23.1(455B), 23.4(455B) and 567 – Chapter 24.

For sources constructed, modified or reconstructed prior to July 21, 1999, the emission of particulate matter from any process shall not exceed the amount determined from Table I, or amount specified in a permit if based on an emission standard of 0.1 grain per standard cubic foot of exhaust gas or established from standards provided in 23.1(455B) and 23.4(455B). Authority for Requirement: 567 IAC 23.3(2)"a"

<u>Fugitive Dust:</u> Attainment and Unclassified Areas - A person shall take reasonable precautions to prevent particulate matter from becoming airborne in quantities sufficient to cause a nuisance as defined in Iowa Code section 657.1 when the person allows, causes or permits any materials to be handled, transported or stored or a building, its appurtenances or a construction haul road to be

used, constructed, altered, repaired or demolished, with the exception of farming operations or dust generated by ordinary travel on unpaved roads. Ordinary travel includes routine traffic and road maintenance activities such as scarifying, compacting, transporting road maintenance surfacing material, and scraping of the unpaved public road surface. (the preceding sentence is State Only) All persons, with the above exceptions, shall take reasonable precautions to prevent the discharge of visible emissions of fugitive dusts beyond the lot line of the property on which the emissions originate. The public highway authority shall be responsible for taking corrective action in those cases where said authority has received complaints of or has actual knowledge of dust conditions which require abatement pursuant to this subrule. Reasonable precautions may include, but not be limited to, the following procedures.

- 1. Use, where practical, of water or chemicals for control of dusts in the demolition of existing buildings or structures, construction operations, the grading of roads or the clearing of land.
- 2. Application of suitable materials, such as but not limited to asphalt, oil, water or chemicals on unpaved roads, material stockpiles, race tracks and other surfaces which can give rise to airborne dusts.
- 3. Installation and use of containment or control equipment, to enclose or otherwise limit the emissions resulting from the handling and transfer of dusty materials, such as but not limited to grain, fertilizer or limestone.
- 4. Covering, at all times when in motion, open-bodied vehicles transporting materials likely to give rise to airborne dusts.
- 5. Prompt removal of earth or other material from paved streets or to which earth or other material has been transported by trucking or earth-moving equipment, erosion by water or other means.
- 6. Reducing the speed of vehicles traveling over on-property surfaces as necessary to minimize the generation of airborne dusts.

Authority for Requirement: 567 IAC 23.3(2)"c"

NSPS and NESHAP Applicability

The facility is subject to 40 CFR 63 Subpart A – NESHAP General Provisions. EP-4, EP-9, EP-14, EP-15, EP-16 are subject to National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines (RICE NESHAP) [40 CFR Part 63 Subpart ZZZZ].

Authority for Requirement: 567 IAC 23.1(4)"a" and "c3"

40 CFR 63 Subpart A and Subpart ZZZZ

EP-11 is subject to NSPS Subpart Kb – Standards of Performance for Volatile Organic Liquid Storage Vessels (Including Petroleum Liquid Storage Vessels) for Which Construction, Reconstruction, or Modification Commenced After July 23, 1984

Authority for Requirement: 567 IAC 23.1(2)"ddd"

40 CFR Part 60 Subpart Kb (§60.110b – §60.117b)

III. Emission Point-Specific Conditions

Facility Name: IPL-Centerville Combustion Turbines and Diesels Station

Permit Number: 02-TV-023R3

Emission Point ID Number: EP-1

Associated Equipment

Associated Emission Unit ID Number: EU-1

Emission Unit vented through this Emission Point: EU-1 Emission Unit Description: Combustion Turbine #1

Raw Material/Fuel: #1 or #2 Fuel Oil Rated Capacity: 2,719 gal/hr (30 MW)

Applicable Requirements

Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

The emissions from this emission point shall not exceed the levels specified below.

Pollutant: Opacity

Emission Limit(s): 40%¹

Authority for Requirement: Iowa DNR Construction Permit 89-A-141-S2

567 IAC 23.3(2)"d"

¹ An exceedance of the indicator opacity of 25% will require the owner/operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedances continue after the corrections, the DNR may require additional proof to demonstrate compliance (e.g., stack testing).

Pollutant: PM

Emission Limit(s): 0.6 lb/mmbtu

Authority for Requirement: Iowa DNR Construction Permit 89-A-141-S2

567 IAC 23.3(2)"b"

Pollutant: PM₁₀

Emission Limit(s): 30 lb/hr

Authority for Requirement: Iowa DNR Construction Permit 89-A-141-S2

Pollutant: SO₂

Emission Limit(s): 2.5 lb/mmbtu

Authority for Requirement: 567 IAC 23.3(3)"b"(2)

Pollutant: NO_x

Emission Limit(s): 350.0 lb/hr

Authority for Requirement: Iowa DNR Construction Permit 89-A-141-S2

Pollutant: NO_x⁽²⁾

Emission Limit(s): 249 tons/yr

Authority for Requirement: Iowa DNR Construction Permit 89-A-141-S2

(2) Plantwide limit to remain PSD minor calculated using Equation in Operational Limits and

Requirements, Process throughput Section A.

Operational Limits & Requirements

The owner/operator of this equipment shall comply with the operational limits and requirements listed below.

Process throughput:

A. Plantwide nitrogen oxide emissions shall not exceed 249 tons per twelve month rolling period, as calculated by the following formula:

$$ER_{\text{nox}} = 0.0644 \text{ T}_{\text{FO}} + 0.35 \text{ SE}_{\text{FO}} + 0.325 \text{ DG}_{\text{FO}}$$

where:

ER_{NOx} =Total NOx emission rate, in tons per 12 month rolling period.

T_{FO} = Fuel oil usage in the turbines (1000 gal), per 12 month rolling period.

SE_{FO} = Fuel oil usage in the starting engines (1000 gal), per 12 month rolling period.

DG_{FO} = Fuel oil usage in the diesel generator (1000 gal), per 12 month rolling period.

- B. This unit shall combust only No. 1 or No. 2 fuel oil.
- C. The maximum sulfur content of the fuel oil shall be 0.36% sulfur by weight.

Reporting & Record keeping:

All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the DNR. These records shall demonstrate compliance with all applicable operating limits. Records shall be legible and maintained in an orderly manner.

- A. The owner or operator shall keep records of the amount of fuel oil burned in the turbines, and update the rolling twelve month total monthly.
- B. The owner or operator shall calculate the plantwide NO_x emission rate, according to the formula in Operational Limits and Requirements Section A, on a monthly basis.

C. The owner or operator shall keep records of the sulfur content of the fuel oil. This may be demonstrated by ASTM test methods of each tank received, or by fuel oil vendor certification.

Authority for Requirement: Iowa DNR Construction Permit 89-A-141-S2

Cross-State Air Pollution Rule (CSAPR) (a.k.a., Transport Rule (TR))

Pollutant: Nitrogen Oxides (NO_x) Annual, Nitrogen Oxides (NO_x) Ozone Season, Sulfur

Dioxide (SO₂) Group 1

Emission Limits: Nitrogen Oxides and Sulfur Dioxide Allowances

Authority for Requirement: 40 CFR Part 97 (See appendix for requirements)

Emission Point Characteristics

The emission point shall conform to the specifications listed below.

Stack Height, (ft, from the ground): 33.2 Stack Opening, (inches): 120 in. x 204 in Exhaust Flow Rate (acfm): 655,000 Exhaust Temperature (°F): 875

Discharge Style: Vertical unobstructed

Authority for Requirement: Iowa DNR Construction Permit 89-A-141-S2

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that either the temperature or flowrate above are different than the values stated, the owner or operator shall submit a request to the Department within thirty (30) days of the discovery to determine if a permit amendment is required or submit a permit application requesting to amend the permit.

Monitoring Requirements

The owner/operator of this equipment shall comply with the monitoring requirements listed below.

Agency Approved Operation & Maintenance Plan Required?	Yes 🗌 No 🖂
Facility Maintained Operation & Maintenance Plan Required?	Yes 🗌 No 🖂
Compliance Assurance Monitoring (CAM) Plan Required?	Yes 🗌 No 🖂
Authority for Requirement: 567 IAC 22.108(3)	

Associated Equipment

Associated Emission Unit ID Number: EU-2

Emission Unit vented through this Emission Point: EU-2

Emission Unit Description: Startup Engine #1

Raw Material/Fuel: #1 or #2 Fuel Oil Rated Capacity: 40 gal/hr (600 hp)

Applicable Requirements

Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

The emissions from this emission point shall not exceed the levels specified below.

Pollutant: Opacity

Emission Limit(s): 40%¹

Authority for Requirement: Iowa DNR Construction Permit 98-A-097-S1

567 IAC 23.3(2)"d"

¹ An exceedance of the indicator opacity of 25% will require the owner/operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedances continue after the corrections, the DNR may require additional proof to demonstrate compliance (e.g., stack testing).

Pollutant: PM

Emission Limit(s): 0.6 lb/mmbtu

Authority for Requirement: Iowa DNR Construction Permit 98-A-097-S1

567 IAC 23.3(2)"b"

Pollutant: PM₁₀

Emission Limit(s): 2.0 lb/hr

Authority for Requirement: Iowa DNR Construction Permit 98-A-097-S1

Pollutant: SO₂

 SO_2

Emission Limit(s): 2.5 lb/mmbtu

Authority for Requirement: 567 IAC 23.3(3)"b"(2)

Pollutant: NO_x

Emission Limit(s): 28.0 lb/hr

Authority for Requirement: Iowa DNR Construction Permit 98-A-097-S1

Pollutant: NO_x⁽²⁾

Emission Limit(s): 249 tons/yr

Authority for Requirement: Iowa DNR Construction Permit 98-A-097-S1

(2) Plantwide limit to remain PSD minor calculated using Equation in Operational Limits and

Requirements, Process throughput Section A.

Operational Limits & Requirements

The owner/operator of this equipment shall comply with the operational limits and requirements listed below.

Process throughput:

A. Plantwide nitrogen oxide emissions shall not exceed 249 tons per twelve month rolling period, as calculated by the following formula:

$$ER_{nox} = 0.0644 T_{FO} + 0.35 SE_{FO} + 0.325 DG_{FO}$$

where:

ER_{NOx} =Total NOx emission rate, in tons per 12 month rolling period.

 T_{FO} = Fuel oil usage in the turbines (1000 gal), per 12 month rolling period.

SE_{FO} = Fuel oil usage in the starting engines (1000 gal), per 12 month rolling period.

DG_{FO} =Fuel oil usage in the diesel generator (1000 gal), per 12 month rolling period.

- B. This unit shall combust only No. 1 or No. 2 fuel oil.
- C. The maximum sulfur content of the fuel oil shall be 0.36% sulfur by weight
- D. This unit may operator a maximum of 3.4 hours each day.
- E. This unit may operator a maximum of 800 hours per twelve month rolling period.

Reporting & Record keeping:

All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the DNR. These records shall demonstrate compliance with all applicable operating limits. Records shall be legible and maintained in an orderly manner.

- A. The owner or operator shall keep records of the amount of fuel oil burned in the turbines, and update the rolling twelve month total monthly.
- B. The owner or operator shall calculate the plantwide NO_x emission rate, according to the formula in Operational Limits and Requirements Section A, on a monthly basis.
- C. The owner or operator shall keep records of the sulfur content of the fuel oil. This may be demonstrated by ASTM test methods of each tank received, or by fuel oil vendor certification.

- D. The owner or operator shall record the hours this unit operates each day.
- E. The owner or operator shall update monthly the total rolling twelve month total hours this unit is operated.

Authority for Requirement: Iowa DNR Construction Permit 98-A-097-S1

NESHAP Requirements

The black start engine is subject to 40 CFR 63 Subpart ZZZZ - National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines (RICE). According to 40 CFR 63.6590(a)(1)(iii) this black start engine, located at an area source, is an existing stationary RICE as it was constructed prior to June 12, 2006.

Compliance Date

Per 63.6595(a)(1) you must comply with the provisions of Subpart ZZZZ that are applicable by May 3, 2013.

Operation and Maintenance Requirements 40 CFR 63.6603, 63.6625, and Tables 2d and 6 to Subpart ZZZZ

- 1. Change oil and filter every 500 hours of operation or annually, whichever comes first. (See 63.6625(i) for the oil analysis option to extend time frame of requirements.)
- 2. Inspect air cleaner every 1000 hours of operation or annually, whichever comes first, and replace as necessary.
- 3. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary.
- 4. Operate and maintain the stationary RICE and after-treatment control device (if any) according to the manufacturer's emission related written instructions or develop your own maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions.
- 5. Minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes.

Notification and Reporting Requirements 40 CFR 63.6645 and 6650

- 1. An initial notification is not required per 40 CFR 63.6645(a)(5).
- 2. Comply with applicable notification requirements in 40 CFR 63.6645 and reporting requirements in 40 CFR 63.6650.

Recordkeeping Requirements 40 CFR 63.6655

- 1. Keep records of the maintenance conducted on the stationary RICE in order to demonstrate that you operated and maintained the stationary RICE and after-treatment control device (if any) according to your own maintenance plan.
- 2. Comply with applicable recordkeeping requirements in 40 CFR 63.6655.

Authority for Requirement: 40 CFR Part 63 Subpart ZZZZ

567 IAC 23.1(4)"cz"

Emission Point Characteristics

The emission point shall conform to the specifications listed below.

Stack Height, (ft, from the ground): 35

Stack Opening, (inches, dia.): 8 Exhaust Flow Rate (acfm): 470 Exhaust Temperature (°F): 450

Discharge Style: Vertical unobstructed

Authority for Requirement: Iowa DNR Construction Permit 98-A-097-S1

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that either the temperature or flowrate above are different than the values stated, the owner or operator shall submit a request to the Department within thirty (30) days of the discovery to determine if a permit amendment is required or submit a permit application requesting to amend the permit.

Monitoring Requirements

The owner/operator of this equipment shall comply with the monitoring requirements listed below.

 Agency Approved Operation & Maintenance Plan Required?
 Yes □ No ⋈

 Facility Maintained Operation & Maintenance Plan Required?
 Yes □ No ⋈

 Compliance Assurance Monitoring (CAM) Plan Required?
 Yes □ No ⋈

Authority for Requirement: 567 IAC 22.108(3)

Associated Equipment

Associated Emission Unit ID Number: EU-6

Emission Unit vented through this Emission Point: EU-6

Emission Unit Description: Combustion Turbine #2

Raw Material/Fuel: #1 or #2 Fuel Oil Rated Capacity: 2,719 gal/hr (30 MW)

Applicable Requirements

Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

The emissions from this emission point shall not exceed the levels specified below.

Pollutant: Opacity

Emission Limit(s): 40%¹

Authority for Requirement: Iowa DNR Construction Permit 98-A-096-S1

567 IAC 23.3(2)"d"

¹ An exceedance of the indicator opacity of 25% will require the owner/operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedances continue after the corrections, the DNR may require additional proof to demonstrate compliance (e.g., stack testing).

Pollutant: PM

Emission Limit(s): 0.6 lb/mmbtu

Authority for Requirement: Iowa DNR Construction Permit 98-A-096-S1

567 IAC 23.3(2)"b"

Pollutant: PM₁₀

Emission Limit(s): 30 lb/hr

Authority for Requirement: Iowa DNR Construction Permit 98-A-096-S1

Pollutant: SO₂

Emission Limit(s): 2.5 lb/mmbtu

Authority for Requirement: 567 IAC 23.3(3)"b"(2)

Pollutant: NO_x

Emission Limit(s): 350.0 lb/hr

Authority for Requirement: Iowa DNR Construction Permit 98-A-096-S1

Pollutant: $NO_x^{(2)}$

Emission Limit(s): 249 tons/yr

Authority for Requirement: Iowa DNR Construction Permit 98-A-096-S1

(2) Plantwide limit to remain PSD minor calculated using Equation in Operational Limits and

Requirements, Process throughput Section A.

Operational Limits & Requirements

The owner/operator of this equipment shall comply with the operational limits and requirements listed below.

Process throughput:

A. Plantwide nitrogen oxide emissions shall not exceed 249 tons per twelve month rolling period, as calculated by the following formula:

$$ER_{\text{nox}} = 0.0644 \text{ T}_{\text{FO}} + 0.35 \text{ SE}_{\text{FO}} + 0.325 \text{ DG}_{\text{FO}}$$

where:

ER_{NOx} =Total NOx emission rate, in tons per 12 month rolling period.

 T_{FO} = Fuel oil usage in the turbines (1000 gal), per 12 month rolling period.

SE_{FO} = Fuel oil usage in the starting engines (1000 gal), per 12 month rolling period.

DG_{FO} =Fuel oil usage in the diesel generator (1000 gal), per 12 month rolling period.

- B. This unit shall combust only No. 1 or No. 2 fuel oil.
- C. The maximum sulfur content of the fuel oil shall be 0.36% sulfur by weight

Reporting & Record keeping:

All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the DNR. These records shall demonstrate compliance with all applicable operating limits. Records shall be legible and maintained in an orderly manner.

- A. The owner or operator shall keep records of the amount of fuel oil burned in the turbines, and update the rolling twelve month total monthly.
- B. The owner or operator shall calculate the plantwide NO_x emission rate, according to the formula in Operational Limits and Requirements Section A, on a monthly basis.
- C. The owner or operator shall keep records of the sulfur content of the fuel oil. This may be demonstrated by ASTM test methods of each tank received, or by fuel oil vendor certification.

Authority for Requirement: Iowa DNR Construction Permit 98-A-096-S1

Cross-State Air Pollution Rule (CSAPR) (a.k.a., Transport Rule (TR))

Pollutant: Nitrogen Oxides (NO_x) Annual, Nitrogen Oxides (NO_x) Ozone Season, Sulfur

Dioxide (SO₂) Group 1

Emission Limits: Nitrogen Oxides and Sulfur Dioxide Allowances

Authority for Requirement: 40 CFR Part 97 (See appendix for requirements)

Emission Point Characteristics

The emission point shall conform to the specifications listed below.

Stack Height, (ft, from the ground): 33.8 Stack Opening, (inches): 120 in. x 204 in Exhaust Flow Rate (acfm): 655,000 Exhaust Temperature (°F): 875

Discharge Style: Vertical unobstructed

Authority for Requirement: Iowa DNR Construction Permit 98-A-096-S1

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that either the temperature or flowrate above are different than the values stated, the owner or operator shall submit a request to the Department within thirty (30) days of the discovery to determine if a permit amendment is required or submit a permit application requesting to amend the permit.

Monitoring Requirements

The owner/operator of this equipment shall comply with the monitoring requirements listed below.

Agency Approved Operation & Maintenance Plan Required?	Yes 🗌 No 🖂
Facility Maintained Operation & Maintenance Plan Required?	Yes 🗌 No 🖂
Compliance Assurance Monitoring (CAM) Plan Required?	Yes 🗌 No 🖂

Authority for Requirement: 567 IAC 22.108(3)

Associated Equipment

Associated Emission Unit ID Number: EU-7

-____

Emission Unit vented through this Emission Point: EU-7

Emission Unit Description: Startup Engine #2

Raw Material/Fuel: #1 or #2 Fuel Oil Rated Capacity: 40 gal/hr (600 HP)

Applicable Requirements

Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

The emissions from this emission point shall not exceed the levels specified below.

Pollutant: Opacity

Emission Limit(s): 40%¹

Authority for Requirement: Iowa DNR Construction Permit 98-A-098-S1

567 IAC 23.3(2)"d"

¹ An exceedance of the indicator opacity of 25% will require the owner/operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedances continue after the corrections, the DNR may require additional proof to demonstrate compliance (e.g., stack testing).

Pollutant: PM

Emission Limit(s): 0.6 lb/mmbtu

Authority for Requirement: Iowa DNR Construction Permit 98-A-098-S1

567 IAC 23.3(2)"b"

Pollutant: PM₁₀

Emission Limit(s): 2.0 lb/hr

Authority for Requirement: Iowa DNR Construction Permit 98-A-098-S1

Pollutant: SO₂

Emission Limit(s): 2.5 lb/mmbtu

Authority for Requirement: 567 IAC 23.3(3)"b"(2)

Pollutant: NO_x

Emission Limit(s): 28.0 lb/hr

Authority for Requirement: Iowa DNR Construction Permit 98-A-098-S1

Pollutant: $NO_x^{(2)}$

Emission Limit(s): 249 tons/yr

Authority for Requirement: Iowa DNR Construction Permit 98-A-098-S1

(2) Plantwide limit to remain PSD minor calculated using Equation in Operational Limits and

Requirements, Process throughput Section A.

Operational Limits & Requirements

The owner/operator of this equipment shall comply with the operational limits and requirements listed below.

Process throughput:

A. Plantwide nitrogen oxide emissions shall not exceed 249 tons per twelve month rolling period, as calculated by the following formula:

$$ER_{nox} = 0.0644 T_{FO} + 0.35 SE_{FO} + 0.325 DG_{FO}$$

where:

ER_{NOx} =Total NOx emission rate, in tons per 12 month rolling period.

 T_{FO} = Fuel oil usage in the turbines (1000 gal), per 12 month rolling period.

SE_{FO} = Fuel oil usage in the starting engines (1000 gal), per 12 month rolling period.

DG_{FO} =Fuel oil usage in the diesel generator (1000 gal), per 12 month rolling period.

- B. This unit shall combust only No. 1 or No. 2 fuel oil.
- C. The maximum sulfur content of the fuel oil shall be 0.36% sulfur by weight
- D. This unit may operator a maximum of 3.4 hours each day.
- E. This unit may operator a maximum of 800 hours per twelve month rolling period.

Reporting & Record keeping:

All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the DNR. These records shall demonstrate compliance with all applicable operating limits. Records shall be legible and maintained in an orderly manner.

- A. The owner or operator shall keep records of the amount of fuel oil burned in the turbines, and update the rolling twelve month total monthly.
- B. The owner or operator shall calculate the plantwide NO_x emission rate, according to the formula in Operational Limits and Requirements Section A, on a monthly basis.

- C. The owner or operator shall keep records of the sulfur content of the fuel oil. This may be demonstrated by ASTM test methods of each tank received, or by fuel oil vendor certification.
- D. The owner or operator shall record the hours this unit operates each day.
- E. The owner or operator shall update monthly the total rolling twelve month total hours this unit is operated.

Authority for Requirement: Iowa DNR Construction Permit 98-A-098-S1

NESHAP Requirements

The black start engine is subject to 40 CFR 63 Subpart ZZZZ - National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines (RICE). According to 40 CFR 63.6590(a)(1)(iii) this black start engine, located at an area source, is an existing stationary RICE as it was constructed prior to June 12, 2006.

Compliance Date

Per 63.6595(a)(1) you must comply with the provisions of Subpart ZZZZ that are applicable by May 3, 2013.

Operation and Maintenance Requirements 40 CFR 63.6603, 63.6625, and Tables 2d and 6 to Subpart ZZZZ

- 1. Change oil and filter every 500 hours of operation or annually, whichever comes first. (See 63.6625(i) for the oil analysis option to extend time frame of requirements.)
- 2. Inspect air cleaner every 1000 hours of operation or annually, whichever comes first, and replace as necessary.
- 3. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary.
- 4. Operate and maintain the stationary RICE and after-treatment control device (if any) according to the manufacturer's emission related written instructions or develop your own maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions.
- 5. Minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes.

Notification and Reporting Requirements 40 CFR 63.6645 and 6650

- 1. An initial notification is not required per 40 CFR 63.6645(a)(5).
- 2. Comply with applicable notification requirements in 40 CFR 63.6645 and reporting requirements in 40 CFR 63.6650.

Recordkeeping Requirements 40 CFR 63.6655

- 1. Keep records of the maintenance conducted on the stationary RICE in order to demonstrate that you operated and maintained the stationary RICE and after-treatment control device (if any) according to your own maintenance plan.
- 2. Comply with applicable recordkeeping requirements in 40 CFR 63.6655.

Authority for Requirement: 40 CFR Part 63 Subpart ZZZZ 567 IAC 23.1(4)"cz"

Emission Point Characteristics

The emission point shall conform to the specifications listed below.

Stack Height, (ft, from the ground): 35

Stack Opening, (inches, dia.): 8 Exhaust Flow Rate (acfm): 470 Exhaust Temperature (°F): 450

Discharge Style: Vertical unobstructed

Authority for Requirement: Iowa DNR Construction Permit 98-A-098-S1

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that either the temperature or flowrate above are different than the values stated, the owner or operator shall submit a request to the Department within thirty (30) days of the discovery to determine if a permit amendment is required or submit a permit application requesting to amend the permit.

Monitoring Requirements

The owner/operator of this equipment shall comply with the monitoring requirements listed below.

Agency Approved Operation & Maintenance Plan Required?	Yes 🗌 No 🖂
Facility Maintained Operation & Maintenance Plan Required?	Yes 🗌 No 🖂
Compliance Assurance Monitoring (CAM) Plan Required?	Yes 🗌 No 🖂
Authority for Requirement: 567 IAC 22.108(3)	

Associated Equipment

Associated Emission Unit ID Number: EU-11

Emission Unit vented through this Emission Point: EU-11

Emission Unit Description: Storage Tank Raw Material/Fuel: #1 or #2 Fuel Oil Rated Capacity: 300,000 gallons

Applicable Requirements

Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

The emissions from this emission point shall not exceed the levels specified below.

See Plantwide Conditions

Operational Limits & Requirements

The owner/operator of this equipment shall comply with the operational limits and requirements listed below.

Operating Limit:

A. The owner or operator shall not store any liquids with a maximum true vapor pressure (as defined in 40 CFR 60.111b) equal to or greater than 3.5 kPa in this tank.

Authority for Requirement: Iowa DNR Construction Permit 01-A-888

Reporting & Record keeping:

All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the DNR. These records shall demonstrate compliance with all applicable operating limits. Records shall be legible and maintained in an orderly manner.

- A. The owner or operator shall keep records of the material stored in this tank, along with their maximum true vapor pressure.
- B. The owner or operator shall keep readily accessible records showing the dimensions of the storage vessel and an analysis showing the capacity of the storage vessel for the life of the source.

Authority for Requirement: Iowa DNR Construction Permit 01-A-888

40 CFR 60.116b(b) 567 IAC 23.1(2)"ddd"

NESHAP Applicability

This equipment is subject to NSPS Subpart Kb – Standards of Performance for Volatile Organic Liquid Storage Vessels (Including Petroleum Liquid Storage Vessels) for Which Construction, Reconstruction, or Modification Commenced After July 23, 1984

Authority for Requirement: 567 IAC 23.1(2) "ddd"

40 CFR Part 60 Subpart Kb (§60.110b – §60.117b)

Emission Point Characteristics

The emission point shall conform to the specifications listed below.

Stack Height, (ft, from the ground): 27.6

Stack Opening, (inches, dia.): 6

Exhaust Flow Rate (scfm): NA - Vent Exhaust Temperature (°F): Ambient Discharge Style: Vertical obstructed

Authority for Requirement: Iowa DNR Construction Permit 01-A-888

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that either the temperature or flowrate above are different than the values stated, the owner or operator shall submit a request to the Department within thirty (30) days of the discovery to determine if a permit amendment is required or submit a permit application requesting to amend the permit.

Monitoring Requirements

The owner/operator of this equipment shall comply with the monitoring requirements listed below.

Agency Approved Operation & Maintenance Plan Required?	Yes No
Facility Maintained Operation & Maintenance Plan Required?	Yes 🗌 No 🖂
Compliance Assurance Monitoring (CAM) Plan Required?	Yes 🗌 No 🖂

Authority for Requirement: 567 IAC 22.108(3)

Associated Equipment

Associated Emission Unit ID Number: EU-14

Emission Unit vented through this Emission Point: EU-14

Emission Unit Description: Diesel Generator #1

Raw Material/Fuel: #1 or #2 Fuel Oil

Rated Capacity: 154 gal/hr

Applicable Requirements

Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

The emissions from this emission point shall not exceed the levels specified below.

Pollutant: Opacity

Emission Limit(s): 40%¹

Authority for Requirement: Iowa DNR Construction Permit 98-A-099-S1

567 IAC 23.3(2)"d"

¹ An exceedance of the indicator opacity of 25% will require the owner/operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedances continue after the corrections, the DNR may require additional proof to demonstrate compliance (e.g., stack testing).

Pollutant: PM

Emission Limit(s): 0.6 lb/mmbtu

Authority for Requirement: 567 IAC 23.3(2)"b"

Pollutant: PM₁₀

Emission Limit(s): 9.0 lb/hr

Authority for Requirement: Iowa DNR Construction Permit 98-A-099-S1

Pollutant: SO₂

 \mathbf{SO}_2

Emission Limit(s): 2.5 lb/mmbtu

Authority for Requirement: 567 IAC 23.3(3)"b"(2)

Pollutant: NO_x

Emission Limit(s): 100.0 lb/hr

Authority for Requirement: Iowa DNR Construction Permit 98-A-099-S1

Pollutant: $NO_x^{(2)}$

Emission Limit(s): 249 tons/yr

Authority for Requirement: Iowa DNR Construction Permit 98-A-099-S1

(2) Plantwide limit to remain PSD minor calculated using Equation in Operational Limits and

Requirements, Process throughput Section A.

Operational Limits & Requirements

The owner/operator of this equipment shall comply with the operational limits and requirements listed below.

Process throughput:

A. Plantwide nitrogen oxide emissions shall not exceed 249 tons per twelve month rolling period, as calculated by the following formula:

 $ER_{nox} = 0.0644 T_{FO} + 0.35 SE_{FO} + 0.325 DG_{FO}$

where:

 $ER_{NOx} =$ Total NOx emission rate, in tons per 12 month rolling period.

T_{FO} = Fuel oil usage in the turbines (1000 gal), per 12 month rolling period.

SE_{FO} = Fuel oil usage in the starting engines (1000 gal), per 12 month rolling period.

DG_{FO} = Fuel oil usage in the diesel generator (1000 gal), per 12 month rolling period.

- B. This unit shall combust only No. 1 or No. 2 fuel oil.
- C. The maximum sulfur content of the fuel oil shall be 0.36% sulfur by weight

Reporting & Record keeping:

All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the DNR. These records shall demonstrate compliance with all applicable operating limits. Records shall be legible and maintained in an orderly manner.

- A. The owner or operator shall keep records of the amount of fuel oil burned in the turbines, and update the rolling twelve month total monthly.
- B. The owner or operator shall calculate the plantwide NO_x emission rate, according to the formula in Operational Limits and Requirements Section A, on a monthly basis.
- C. The owner or operator shall keep records of the sulfur content of the fuel oil. This may be demonstrated by ASTM test methods of each tank received, or by fuel oil vendor certification.

Authority for Requirement: Iowa DNR Construction Permit 98-A-099-S1

NESHAP Requirements

The emergency engine is subject to 40 CFR 63 Subpart ZZZZ - National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines (RICE). According to 40 CFR 63.6590(a)(1)(iii) this compression ignition emergency engine, located at an area source, is an existing stationary RICE as it was constructed prior to June 12, 2006.

Compliance Date

Per 63.6595(a)(1) you must comply with the provisions of Subpart ZZZZ that are applicable by May 3, 2013.

Operation and Maintenance Requirements 40 CFR 63.6603, 63.6625, 63.6640 and Tables 2d and 6 to Subpart ZZZZ

- 1. Change oil and filter every 500 hours of operation or annually, whichever comes first. (See 63.6625(i) for the oil analysis option to extend time frame of requirements.)
- 2. Inspect air cleaner every 1000 hours of operation or annually, whichever comes first, and replace as necessary.
- 3. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary.
- 4. Operate and maintain the stationary RICE and after-treatment control device (if any) according to the manufacturer's emission related written instructions or develop your own maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions.
- 5. Install a non-resettable hour meter if one is not already installed.
- 6. Minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes.

Operating Limits 40 CFR 63.6640(f)

- 1. Any operation other than emergency operation, maintenance and testing, and operation in non-emergency situations (*up to*) 50 hours per year is prohibited.
- 2. There is no time limit on the use of emergency stationary RICE in emergency situations.
- 3. You may operate your emergency stationary RICE up to 100 combined hours per calendar year for maintenance checks and readiness testing. See 40 CFR 63.6640(f)(2) for additional information and restrictions.
- 4. You may operate your emergency stationary RICE up to 50 hours per calendar year for non-emergency situations, but those 50 hours are counted toward the 100 hours of maintenance and testing. Except as provided in 40 CFR 63.6640(f)(4)(i) and (ii), the 50 hours per year for non-emergency situations cannot be used for peak shaving, or to generate income for a facility to supply power to an electric grid or otherwise supply power as part of a financial arrangement with another entity.

Recordkeeping Requirements 40 CFR 63.6655

- 1. Keep records of the maintenance conducted on the stationary RICE.
- 2. Keep records of the hours of operation of the engine that is recorded through the non-resettable hour meter. Document how many hours are spent for emergency operation, including what classified the operation as emergency and how many hours are spent for non-emergency operation. See 40 CFR 63.6655(f) for additional information.

Notification and Reporting Requirements 40 CFR 63.6645, 63.6650 and Table 2d to Subpart ZZZZ

- 1. An initial notification is not required per 40 CFR 63.6645(a)(5)
- 2. A report may be required for failure to perform the work practice requirements on the schedule required in Table 2d. (See Footnote 2 of Table 2d for more information.)

Authority for Requirement: 40 CFR 63 Subpart ZZZZ 567 IAC 23.1(4)"cz"

Emission Point Characteristics

The emission point shall conform to the specifications listed below.

Stack Testing:

Pollutant - NO_x

1st Stack Test to be Completed by (1)

Test Method – 40 CFR 60, Appendix A, Method 7E

Authority for Requirement - Iowa DNR Construction Permit 98-A-099-S1

¹Required first time calculated plantwide NOx emissions exceed 200 tons per twelve month rolling total.

The owner of this equipment or the owner's authorized agent shall provide written notice to the Director, not less than 30 days before a required stack test or performance evaluation of a continuous emission monitor. Results of the test shall be submitted in writing to the Director in the form of a comprehensive report within 6 weeks of the completion of the testing. 567 IAC 25.1(7)

Stack Height, (ft, from the ground): 55.0

Stack Opening, (inches, dia): 24 Exhaust Flow Rate (acfm): 6,580 Exhaust Temperature (°F): 450

Discharge Style: Vertical unobstructed

Authority for Requirement: Iowa DNR Construction Permit 98-A-099-S1

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that either the temperature or flowrate above are different than the values stated, the owner or operator shall submit a request to the Department within thirty (30) days of the discovery to determine if a permit amendment is required or submit a permit application requesting to amend the permit.

Monitoring Requirements	
The owner/operator of this equipment shall comply with the monitoring Agency Approved Operation & Maintenance Plan Required?	requirements listed below Yes No
Facility Maintained Operation & Maintenance Plan Required?	Yes 🗌 No 🖂
Compliance Assurance Monitoring (CAM) Plan Required?	Yes 🗌 No 🖂
Authority for Paguirament: 567 IAC 22 108(2)	

Associated Equipment

Associated Emission Unit ID Number: EU-15

Emission Unit vented through this Emission Point: EU-15

Emission Unit Description: Diesel Generator #2

Raw Material/Fuel: #1 or #2 Fuel Oil

Rated Capacity: 154 gal/hr

Applicable Requirements

Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

The emissions from this emission point shall not exceed the levels specified below.

Pollutant: Opacity

Emission Limit(s): 40%¹

Authority for Requirement: Iowa DNR Construction Permit 98-A-100-S1

567 IAC 23.3(2)"d"

¹ An exceedance of the indicator opacity of 25% will require the owner/operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedances continue after the corrections, the DNR may require additional proof to demonstrate compliance (e.g., stack testing).

Pollutant: PM

Emission Limit(s): 0.6 lb/mmbtu

Authority for Requirement: 567 IAC 23.3(2)"b"

Pollutant: PM₁₀

Emission Limit(s): 9.0 lb/hr

Authority for Requirement: Iowa DNR Construction Permit 98-A-100-S1

Pollutant: SO₂

Emission Limit(s): 2.5 lb/mmbtu

Authority for Requirement: 567 IAC 23.3(3)"b"(2)

Pollutant: NO_x

Emission Limit(s): 100.0 lb/hr

Authority for Requirement: Iowa DNR Construction Permit 98-A-100-S1

Pollutant: $NO_x^{(2)}$

Emission Limit(s): 249 tons/yr

Authority for Requirement: Iowa DNR Construction Permit 98-A-100-S1

(2) Plantwide limit to remain PSD minor calculated using Equation in Operational Limits and

Requirements, Process throughput Section A.

Operational Limits & Requirements

The owner/operator of this equipment shall comply with the operational limits and requirements listed below.

Process throughput:

A. Plantwide nitrogen oxide emissions shall not exceed 249 tons per twelve month rolling period, as calculated by the following formula:

$$ER_{nox} = 0.0644 T_{FO} + 0.35 SE_{FO} + 0.325 DG_{FO}$$

where:

ER_{NOx} =Total NOx emission rate, in tons per 12 month rolling period.

 T_{FO} = Fuel oil usage in the turbines (1000 gal), per 12 month rolling period.

SE_{FO} = Fuel oil usage in the starting engines (1000 gal), per 12 month rolling period.

DG_{FO} =Fuel oil usage in the diesel generator (1000 gal), per 12 month rolling period.

- B. This unit shall combust only No. 1 or No. 2 fuel oil.
- C. The maximum sulfur content of the fuel oil shall be 0.36% sulfur by weight

Reporting & Record keeping:

All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the DNR. These records shall demonstrate compliance with all applicable operating limits. Records shall be legible and maintained in an orderly manner.

- A. The owner or operator shall keep records of the amount of fuel oil burned in the turbines, and update the rolling twelve month total monthly.
- B. The owner or operator shall calculate the plantwide NO_x emission rate, according to the formula in Operational Limits and Requirements Section A, on a monthly basis.
- C. The owner or operator shall keep records of the sulfur content of the fuel oil. This may be demonstrated by ASTM test methods of each tank received, or by fuel oil vendor certification.

Authority for Requirement: Iowa DNR Construction Permit 98-A-100-S1

NESHAP Requirements

The emergency engine is subject to 40 CFR 63 Subpart ZZZZ - National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines (RICE). According to 40 CFR 63.6590(a)(1)(iii) this compression ignition emergency engine, located at an area source, is an existing stationary RICE as it was constructed prior to June 12, 2006.

Compliance Date

Per 63.6595(a)(1) you must comply with the provisions of Subpart ZZZZ that are applicable by May 3, 2013.

Operation and Maintenance Requirements 40 CFR 63.6603, 63.6625, 63.6640 and Tables 2d and 6 to Subpart ZZZZ

- 1. Change oil and filter every 500 hours of operation or annually, whichever comes first. (See 63.6625(i) for the oil analysis option to extend time frame of requirements.)
- 2. Inspect air cleaner every 1000 hours of operation or annually, whichever comes first, and replace as necessary.
- 3. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary.
- 4. Operate and maintain the stationary RICE and after-treatment control device (if any) according to the manufacturer's emission related written instructions or develop your own maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions.
- 5. Install a non-resettable hour meter if one is not already installed.
- 6. Minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes.

Operating Limits 40 CFR 63.6640(f)

- 1. Any operation other than emergency operation, maintenance and testing, and operation in non-emergency situations (*up to*) 50 hours per year is prohibited.
- 2. There is no time limit on the use of emergency stationary RICE in emergency situations.
- 3. You may operate your emergency stationary RICE up to 100 combined hours per calendar year for maintenance checks and readiness testing. See 40 CFR 63.6640(f)(2) for additional information and restrictions.
- 4. You may operate your emergency stationary RICE up to 50 hours per calendar year for non-emergency situations, but those 50 hours are counted toward the 100 hours of maintenance and testing. Except as provided in 40 CFR 63.6640(f)(4)(i) and (ii), the 50 hours per year for non-emergency situations cannot be used for peak shaving, or to generate income for a facility to supply power to an electric grid or otherwise supply power as part of a financial arrangement with another entity.

Recordkeeping Requirements 40 CFR 63.6655

- 1. Keep records of the maintenance conducted on the stationary RICE.
- 2. Keep records of the hours of operation of the engine that is recorded through the non-resettable hour meter. Document how many hours are spent for emergency operation,

including what classified the operation as emergency and how many hours are spent for non-emergency operation. See 40 CFR 63.6655(f) for additional information.

Notification and Reporting Requirements 40 CFR 63.6645, 63.6650 and Table 2d to Subpart ZZZZ

- 1. An initial notification is not required per 40 CFR 63.6645(a)(5)
- 2. A report may be required for failure to perform the work practice requirements on the schedule required in Table 2d. (See Footnote 2 of Table 2d for more information.)

Authority for Requirement: 40 CFR 63 Subpart ZZZZ

567 IAC 23.1(4)"cz"

Emission Point Characteristics

The emission point shall conform to the specifications listed below.

Stack Testing:

Pollutant - NO_x

1st Stack Test to be Completed by (1)

Test Method – 40 CFR 60, Appendix A, Method 7E

Authority for Requirement - Iowa DNR Construction Permit 98-A100-S1

The owner of this equipment or the owner's authorized agent shall provide written notice to the Director, not less than 30 days before a required stack test or performance evaluation of a continuous emission monitor. Results of the test shall be submitted in writing to the Director in the form of a comprehensive report within 6 weeks of the completion of the testing. 567 IAC 25.1(7)

Stack Height, (ft, from the ground): 55.0

Stack Opening, (inches, dia): 24 Exhaust Flow Rate (acfm): 6,580 Exhaust Temperature (°F): 450

Discharge Style: Vertical, unobstructed

Authority for Requirement: Iowa DNR Construction Permit 98-A-100-S1

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that either the temperature or flowrate above are different than the values stated, the owner or operator shall submit a request to the Department within thirty (30) days of the discovery to determine if a permit amendment is required or submit a permit application requesting to amend the permit.

¹ Required first time calculated plantwide NOx emissions exceed 200 tons per twelve month rolling total.

Monitoring Requirements The owner/operator of this equipment shall comply with the monitoring requirements listed below.		
Agency Approved Operation & Maintenance Plan Required?	Yes No No	
Facility Maintained Operation & Maintenance Plan Required?	Yes 🗌 No 🖂	

Compliance Assurance Monitoring (CAM) Plan Required? Authority for Requirement: 567 IAC 22.108(3) Yes 🗌 No 🖂

Associated Equipment

Associated Emission Unit ID Number: EU-16

Emission Unit vented through this Emission Point: EU-16

Emission Unit Description: Diesel Generator #3

Raw Material/Fuel: #1 or #2 Fuel Oil

Rated Capacity: 154 gal/hr

Applicable Requirements

Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

The emissions from this emission point shall not exceed the levels specified below.

Pollutant: Opacity

Emission Limit(s): 40%¹

Authority for Requirement: Iowa DNR Construction Permit 98-A-101-S1

567 IAC 23.3(2)"d"

¹ An exceedance of the indicator opacity of 25% will require the owner/operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedances continue after the corrections, the DNR may require additional proof to demonstrate compliance (e.g., stack testing).

Pollutant: PM

Emission Limit(s): 0.6 lb/mmbtu

Authority for Requirement: 567 IAC 23.3(2)"b"

Pollutant: PM₁₀

Emission Limit(s): 9.0 lb/hr

Authority for Requirement: Iowa DNR Construction Permit 98-A-101-S1

Pollutant: SO₂

 SO_2

Emission Limit(s): 2.5 lb/mmbtu

Authority for Requirement: 567 IAC 23.3(3)"b"(2)

Pollutant: NO_x

Emission Limit(s): 100.0 lb/hr

Authority for Requirement: Iowa DNR Construction Permit 98-A-101-S1

Pollutant: $NO_x^{(2)}$

Emission Limit(s): 249 tons/yr

Authority for Requirement: Iowa DNR Construction Permit 98-A-101-S1

(2) Plantwide limit to remain PSD minor calculated using Equation in Operational Limits and

Requirements, Process throughput Section A.

Operational Limits & Requirements

The owner/operator of this equipment shall comply with the operational limits and requirements listed below.

Process throughput:

A. Plantwide nitrogen oxide emissions shall not exceed 249 tons per twelve month rolling period, as calculated by the following formula:

$$ER_{nox} = 0.0644 T_{FO} + 0.35 SE_{FO} + 0.325 DG_{FO}$$

where:

ER_{NOx} =Total NOx emission rate, in tons per 12 month rolling period.

 T_{FO} = Fuel oil usage in the turbines (1000 gal), per 12 month rolling period.

SE_{FO} = Fuel oil usage in the starting engines (1000 gal), per 12 month rolling period.

DG_{FO} =Fuel oil usage in the diesel generator (1000 gal), per 12 month rolling period.

- B. This unit shall combust only No. 1 or No. 2 fuel oil.
- C. The maximum sulfur content of the fuel oil shall be 0.36% sulfur by weight

Reporting & Record keeping:

All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the DNR. These records shall demonstrate compliance with all applicable operating limits. Records shall be legible and maintained in an orderly manner.

- A. The owner or operator shall keep records of the amount of fuel oil burned in the turbines, and update the rolling twelve month total monthly.
- B. The owner or operator shall calculate the plantwide NO_x emission rate, according to the formula in Operational Limits and Requirements Section A, on a monthly basis.
- C. The owner or operator shall keep records of the sulfur content of the fuel oil. This may be demonstrated by ASTM test methods of each tank received, or by fuel oil vendor certification.

Authority for Requirement: Iowa DNR Construction Permit 98-A-101-S1

NESHAP Requirements

The emergency engine is subject to 40 CFR 63 Subpart ZZZZ - National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines (RICE). According to 40 CFR 63.6590(a)(1)(iii) this compression ignition emergency engine, located at an area source, is an existing stationary RICE as it was constructed prior to June 12, 2006.

Compliance Date

Per 63.6595(a)(1) you must comply with the provisions of Subpart ZZZZ that are applicable by May 3, 2013.

Operation and Maintenance Requirements 40 CFR 63.6603, 63.6625, 63.6640 and Tables 2d and 6 to Subpart ZZZZ

- 1. Change oil and filter every 500 hours of operation or annually, whichever comes first. (See 63.6625(i) for the oil analysis option to extend time frame of requirements.)
- 2. Inspect air cleaner every 1000 hours of operation or annually, whichever comes first, and replace as necessary.
- 3. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary.
- 4. Operate and maintain the stationary RICE and after-treatment control device (if any) according to the manufacturer's emission related written instructions or develop your own maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions.
- 5. Install a non-resettable hour meter if one is not already installed.
- 6. Minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes.

Operating Limits 40 CFR 63.6640(f)

- 1. Any operation other than emergency operation, maintenance and testing, and operation in non-emergency situations (*up to*) 50 hours per year is prohibited.
- 2. There is no time limit on the use of emergency stationary RICE in emergency situations.
- 3. You may operate your emergency stationary RICE up to 100 combined hours per calendar year for maintenance checks and readiness testing. See 40 CFR 63.6640(f)(2) for additional information and restrictions.
- 4. You may operate your emergency stationary RICE up to 50 hours per calendar year for non-emergency situations, but those 50 hours are counted toward the 100 hours of maintenance and testing. Except as provided in 40 CFR 63.6640(f)(4)(i) and (ii), the 50 hours per year for non-emergency situations cannot be used for peak shaving, or to generate income for a facility to supply power to an electric grid or otherwise supply power as part of a financial arrangement with another entity.

Recordkeeping Requirements 40 CFR 63.6655

1. Keep records of the maintenance conducted on the stationary RICE.

2. Keep records of the hours of operation of the engine that is recorded through the non-resettable hour meter. Document how many hours are spent for emergency operation, including what classified the operation as emergency and how many hours are spent for non-emergency operation. See 40 CFR 63.6655(f) for additional information.

Notification and Reporting Requirements 40 CFR 63.6645, 63.6650 and Table 2d to Subpart ZZZZ

- 1. An initial notification is not required per 40 CFR 63.6645(a)(5)
- 2. A report may be required for failure to perform the work practice requirements on the schedule required in Table 2d. (See Footnote 2 of Table 2d for more information.)

Authority for Requirement: 40 CFR 63 Subpart ZZZZ

567 IAC 23.1(4)"cz"

Emission Point Characteristics

The emission point shall conform to the specifications listed below.

Stack Testing:

Pollutant - NO_x

1st Stack Test to be Completed by (1)

Test Method – 40 CFR 60, Appendix A, Method 7E

Authority for Requirement - Iowa DNR Construction Permit 98-A101-S1

The owner of this equipment or the owner's authorized agent shall provide written notice to the Director, not less than 30 days before a required stack test or performance evaluation of a continuous emission monitor. Results of the test shall be submitted in writing to the Director in the form of a comprehensive report within 6 weeks of the completion of the testing. 567 IAC 25.1(7)

Stack Height, (ft, from the ground): 55.0

Stack Opening, (inches, dia): 24 Exhaust Flow Rate (acfm): 6,580 Exhaust Temperature (°F): 450

Discharge Style: Vertical, unobstructed

Authority for Requirement: Iowa DNR Construction Permit 98-A-101-S1

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that either the temperature or flowrate above are different than the values stated, the owner or operator shall submit a request to the Department within thirty (30) days of the discovery to determine if a permit amendment is required or submit a permit application requesting to amend the permit.

¹ Required first time calculated plantwide NOx emissions exceed 200 tons per twelve month rolling total.

<u>Monitoring Requirements</u> The owner/operator of this equipment shall comply with the monitoring requirements listed below.						
Agency Approved Operation & Maintenance Plan Required?	Yes 🗌 No 🔀					
Facility Maintained Operation & Maintenance Plan Required?	Yes 🗌 No 🖂					

Compliance Assurance Monitoring (CAM) Plan Required? Authority for Requirement: 567 IAC 22.108(3) Yes 🗌 No 🖂

IV. General Conditions

This permit is issued under the authority of the Iowa Code subsection 455B.133(8) and in accordance with 567 Iowa Administrative Code chapter 22.

G1. Duty to Comply

- 1. The permittee must comply with all conditions of the Title V permit. Any permit noncompliance constitutes a violation of the Act and is grounds for enforcement action; for a permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application. 567 IAC 22.108(9)"a"
- 2. Any compliance schedule shall be supplemental to, and shall not sanction noncompliance with, the applicable requirements on which it is based. 567 IAC 22.105 (2)"h"(3)
- 3. Where an applicable requirement of the Act is more stringent than an applicable requirement of regulations promulgated under Title IV of the Act, both provisions shall be enforceable by the administrator and are incorporated into this permit. 567 IAC 22.108 (1)"b"
- 4. Unless specified as either "state enforceable only" or "local program enforceable only", all terms and conditions in the permit, including provisions to limit a source's potential to emit, are enforceable by the administrator and citizens under the Act. 567 IAC 22.108 (14)
- 5. It shall not be a defense for a permittee, in an enforcement action, that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. 567 IAC 22.108 (9)"b"
- 6. For applicable requirements with which the permittee is in compliance, the permittee shall continue to comply with such requirements. For applicable requirements that will become effective during the permit term, the permittee shall meet such requirements on a timely basis. 567 IAC 22.108(15)"c"

G2. Permit Expiration

- 1. Except as provided in rule 567—22.104(455B), permit expiration terminates a source's right to operate unless a timely and complete application for renewal has been submitted in accordance with rule 567—22.105(455B). 567 IAC 22.116(2)
- 2. To be considered timely, the owner, operator, or designated representative (where applicable) of each source required to obtain a Title V permit shall submit on forms or electronic format specified by the Department to the Air Quality Bureau, Iowa Department of Natural Resources, Air Quality Bureau, 7900 Hickman Rd, Suite #1, Windsor Heights, Iowa 50324, two copies (three if your facility is located in Linn or Polk county) of a complete permit application, at least 6 months but not more than 18 months prior to the date of permit expiration. An additional copy must also be sent to U.S. EPA Region VII, Attention: Chief of Air Permits, 11201 Renner Blvd., Lenexa, KS 66219. Additional copies to local programs or EPA are not required for application materials submitted through the electronic format specified by the Department. The application must include all emission points, emission units, air pollution control equipment, and monitoring devices at the facility. All emissions generating activities, including fugitive emissions, must be included. The definition of a complete application is as indicated in 567 IAC 22.105(2). 567 IAC 22.105

G3. Certification Requirement for Title V Related Documents

Any application, report, compliance certification or other document submitted pursuant to this permit shall contain certification by a responsible official of truth, accuracy, and completeness. All certifications shall state that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete. 567 IAC 22.107 (4)

G4. Annual Compliance Certification

By March 31 of each year, the permittee shall submit compliance certifications for the previous calendar year. The certifications shall include descriptions of means to monitor the compliance status of all emissions sources including emissions limitations, standards, and work practices in accordance with applicable requirements. The certification for a source shall include the identification of each term or condition of the permit that is the basis of the certification; the compliance status; whether compliance was continuous or intermittent; the method(s) used for determining the compliance status of the source, currently and over the reporting period consistent with all applicable department rules. For sources determined not to be in compliance at the time of compliance certification, a compliance schedule shall be submitted which provides for periodic progress reports, dates for achieving activities, milestones, and an explanation of why any dates were missed and preventive or corrective measures. The compliance certification shall be submitted to the administrator, director, and the appropriate DNR Field office. 567 *IAC* 22.108 (15)"e"

G5. Semi-Annual Monitoring Report

By March 31 and September 30 of each year, the permittee shall submit a report of any monitoring required under this permit for the 6 month periods of July 1 to December 31 and January 1 to June 30, respectively. All instances of

deviations from permit requirements must be clearly identified in these reports, and the report must be signed by a responsible official, consistent with 567 IAC 22.107(4). The semi-annual monitoring report shall be submitted to the director and the appropriate DNR Field office. 567 IAC 22.108 (5)

G6. Annual Fee

- 1. The permittee is required under subrule 567 IAC 22.106 to pay an annual fee based on the total tons of actual emissions of each regulated air pollutant. Beginning July 1, 1996, Title V operating permit fees will be paid on July 1 of each year. The fee shall be based on emissions for the previous calendar year.
- 2. The fee amount shall be calculated based on the first 4,000 tons of each regulated air pollutant emitted each year. The fee to be charged per ton of pollutant will be available from the department by June 1 of each year. The Responsible Official will be advised of any change in the annual fee per ton of pollutant.
- 3. The following forms shall be submitted annually by March 31 documenting actual emissions for the previous calendar year.
 - a. Form 1.0 "Facility Identification";
 - b. Form 4.0 "Emissions unit-actual operations and emissions" for each emission unit;
 - c. Form 5.0 "Title V annual emissions summary/fee"; and
 - d. Part 3 "Application certification."
- 4. The fee shall be submitted annually by July 1. The fee shall be submitted with the following forms:
 - a. Form 1.0 "Facility Identification";
 - b. Form 5.0 "Title V annual emissions summary/fee";
 - c. Part 3 "Application certification."
- 5. If there are any changes to the emission calculation form, the department shall make revised forms available to the public by January 1. If revised forms are not available by January 1, forms from the previous year may be used and the year of emissions documented changed. The department shall calculate the total statewide Title V emissions for the prior calendar year and make this information available to the public no later than April 30 of each year.
- 6. Phase I acid rain affected units under section 404 of the Act shall not be required to pay a fee for emissions which occur during the years 1993 through 1999 inclusive.
- 7. The fee for a portable emissions unit or stationary source which operates both in Iowa and out of state shall be calculated only for emissions from the source while operating in Iowa.
- 8. Failure to pay the appropriate Title V fee represents cause for revocation of the Title V permit as indicated in 567 IAC 22.115(1)"d".

G7. Inspection of Premises, Records, Equipment, Methods and Discharges

Upon presentation of proper credentials and any other documents as may be required by law, the permittee shall allow the director or the director's authorized representative to:

- 1. Enter upon the permittee's premises where a Title V source is located or emissions-related activity is conducted, or where records must be kept under the conditions of the permit;
- 2. Have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit:
- 3. Inspect, at reasonable times, any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under the permit; and
- 4. Sample or monitor, at reasonable times, substances or parameters for the purpose of ensuring compliance with the permit or other applicable requirements. 567 IAC 22.108 (15)"b"

G8. Duty to Provide Information

The permittee shall furnish to the director, within a reasonable time, any information that the director may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee also shall furnish to the director copies of records required to be kept by the permit, or for information claimed to be confidential, the permittee shall furnish such records directly to the administrator of EPA along with a claim of confidentiality. 567 IAC 22.108 (9)"e"

G9. General Maintenance and Repair Duties

The owner or operator of any air emission source or control equipment shall:

- 1. Maintain and operate the equipment or control equipment at all times in a manner consistent with good practice for minimizing emissions.
- 2. Remedy any cause of excess emissions in an expeditious manner.
- 3. Minimize the amount and duration of any excess emission to the maximum extent possible during periods of such emissions. These measures may include but not be limited to the use of clean fuels, production cutbacks, or the use of alternate process units or, in the case of utilities, purchase of electrical power until repairs are completed.
- 4. Schedule, at a minimum, routine maintenance of equipment or control equipment during periods of process shutdowns to the maximum extent possible. 567 IAC 24.2(1)

G10. Recordkeeping Requirements for Compliance Monitoring

- 1. In addition to any source specific recordkeeping requirements contained in this permit, the permittee shall maintain the following compliance monitoring records, where applicable:
 - a. The date, place and time of sampling or measurements
 - b. The date the analyses were performed.
 - c. The company or entity that performed the analyses.
 - d. The analytical techniques or methods used.
 - e. The results of such analyses; and
 - f. The operating conditions as existing at the time of sampling or measurement.
 - g. The records of quality assurance for continuous compliance monitoring systems (including but not limited to quality control activities, audits and calibration drifts.)
- 2. The permittee shall retain records of all required compliance monitoring data and support information for a period of at least 5 years from the date of compliance monitoring sample, measurement report or application. Support information includes all calibration and maintenance records and all original strip chart recordings for continuous compliance monitoring, and copies of all reports required by the permit.
- 3. For any source which in its application identified reasonably anticipated alternative operating scenarios, the permittee shall:
 - a. Comply with all terms and conditions of this permit specific to each alternative scenario.
 - b. Maintain a log at the permitted facility of the scenario under which it is operating.
 - c. Consider the permit shield, if provided in this permit, to extend to all terms and conditions under each operating scenario. 567 IAC 22.108(4), 567 IAC 22.108(12)

G11. Evidence used in establishing that a violation has or is occurring.

Notwithstanding any other provisions of these rules, any credible evidence may be used for the purpose of establishing whether a person has violated or is in violation of any provisions herein.

1. Information from the use of the following methods is presumptively credible evidence of whether a violation has

occurred at a source:

- a. A monitoring method approved for the source and incorporated in an operating permit pursuant to 567 Chapter 22;
- b. Compliance test methods specified in 567 Chapter 25; or
- c. Testing or monitoring methods approved for the source in a construction permit issued pursuant to 567 Chapter 22.
- 2. The following testing, monitoring or information gathering methods are presumptively credible testing, monitoring, or information gathering methods:
 - a. Any monitoring or testing methods provided in these rules; or
 - b. Other testing, monitoring, or information gathering methods that produce information comparable to that produced by any method in subrule 21.5(1) or this subrule. 567 IAC 21.5(1)-567 IAC 21.5(2)

G12. Prevention of Accidental Release: Risk Management Plan Notification and Compliance Certification If the permittee is required to develop and register a risk management plan pursuant to section 112(r) of the Act, the permittee shall notify the department of this requirement. The plan shall be filed with all appropriate authorities by the deadline specified by EPA. A certification that this risk management plan is being properly implemented shall be included in the annual compliance certification of this permit. 567 IAC 22.108(6)

G13. Hazardous Release

The permittee must report any situation involving the actual, imminent, or probable release of a hazardous substance into the atmosphere which, because of the quantity, strength and toxicity of the substance, creates an immediate or potential danger to the public health, safety or to the environment. A verbal report shall be made to the department at (515) 281-8694 and to the local police department or the office of the sheriff of the affected county as soon as possible but not later than six hours after the discovery or onset of the condition. This verbal report must be followed up with a written report as indicated in 567 IAC 131.2(2). 567 IAC Chapter 131-State Only

G14. Excess Emissions and Excess Emissions Reporting Requirements

1. Excess Emissions. Excess emission during a period of startup, shutdown, or cleaning of control equipment is not a violation of the emission standard if the startup, shutdown or cleaning is accomplished expeditiously and in a manner consistent with good practice for minimizing emissions. Cleaning of control equipment which does not require the shutdown of the process equipment shall be limited to one six-minute period per one-hour period. An

incident of excess emission (other than an incident during startup, shutdown or cleaning of control equipment) is a violation. If the owner or operator of a source maintains that the incident of excess emission was due to a malfunction, the owner or operator must show that the conditions which caused the incident of excess emission were not preventable by reasonable maintenance and control measures. Determination of any subsequent enforcement action will be made following review of this report. If excess emissions are occurring, either the control equipment causing the excess emission shall be repaired in an expeditious manner or the process generating the emissions shall be shutdown within a reasonable period of time. An expeditious manner is the time necessary to determine the cause of the excess emissions and to correct it within a reasonable period of time. A reasonable period of time is eight hours plus the period of time required to shut down the process without damaging the process equipment or control equipment. A variance from this subrule may be available as provided for in Iowa Code section 455B.143. In the case of an electric utility, a reasonable period of time is eight hours plus the period of time until comparable generating capacity is available to meet consumer demand with the affected unit out of service, unless, the director shall, upon investigation, reasonably determine that continued operation constitutes an unjustifiable environmental hazard and issue an order that such operation is not in the public interest and require a process shutdown to commence immediately.

2. Excess Emissions Reporting

- a. Initial Reporting of Excess Emissions. An incident of excess emission (other than an incident of excess emission during a period of startup, shutdown, or cleaning) shall be reported to the appropriate field office of the department within eight hours of, or at the start of the first working day following the onset of the incident. The reporting exemption for an incident of excess emission during startup, shutdown or cleaning does not relieve the owner or operator of a source with continuous monitoring equipment of the obligation of submitting reports required in 567-subrule 25.1(6). An initial report of excess emission is not required for a source with operational continuous monitoring equipment (as specified in 567-subrule 25.1(1)) if the incident of excess emission continues for less than 30 minutes and does not exceed the applicable emission standard by more than 10 percent or the applicable visible emission standard by more than 10 percent opacity. The initial report may be made by electronic mail (E-mail), in person, or by telephone and shall include as a minimum the following:
 - i. The identity of the equipment or source operation from which the excess emission originated and the associated stack or emission point.
 - ii. The estimated quantity of the excess emission.
 - iii. The time and expected duration of the excess emission.
 - iv. The cause of the excess emission.
 - v. The steps being taken to remedy the excess emission.
 - vi. The steps being taken to limit the excess emission in the interim period.
- b. Written Reporting of Excess Emissions. A written report of an incident of excess emission shall be submitted as a follow-up to all required initial reports to the department within seven days of the onset of the upset condition, and shall include as a minimum the following:
 - i. The identity of the equipment or source operation point from which the excess emission originated and the associated stack or emission point.
 - ii. The estimated quantity of the excess emission.
 - iii. The time and duration of the excess emission.
 - iv. The cause of the excess emission.
 - v. The steps that were taken to remedy and to prevent the recurrence of the incident of excess emission.
 - vi. The steps that were taken to limit the excess emission.
 - vii. If the owner claims that the excess emission was due to malfunction, documentation to support this claim. 567 IAC 24.1(1)-567 IAC 24.1(4)
- 3. Emergency Defense for Excess Emissions. For the purposes of this permit, an "emergency" means any situation arising from sudden and reasonably unforeseeable events beyond the control of the source, including acts of God, which situation requires immediate corrective action to restore normal operation, and that causes the source to exceed a technology-based emission limitation under the permit due to unavoidable increases in emissions attributable to the emergency. An emergency shall not include non-compliance, to the extent caused by improperly designed equipment, lack of preventive maintenance, careless or improper operation or operator error. An emergency constitutes an affirmative defense to an action brought for non-compliance with technology based limitations if it can be demonstrated through properly signed contemporaneous operating logs or other relevant evidence that:

- a. An emergency occurred and that the permittee can identify the cause(s) of the emergency;
- b. The facility at the time was being properly operated;
- c. During the period of the emergency, the permittee took all reasonable steps to minimize levels of emissions that exceeded the emissions standards or other requirements of the permit; and
- d. The permittee submitted notice of the emergency to the director by certified mail within two working days of the time when the emissions limitations were exceeded due to the emergency. This notice fulfills the requirement of paragraph 22.108(5)"b." See G15. This notice must contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken.

In any enforcement proceeding, the permittee seeking to establish the occurrence of an emergency has the burden of proof. This provision is in addition to any emergency or upset provision contained in any applicable requirement. 567 IAC 22.108(16)

G15. Permit Deviation Reporting Requirements

A deviation is any failure to meet a term, condition or applicable requirement in the permit. Reporting requirements for deviations that result in a hazardous release or excess emissions have been indicated above (see G13 and G14). Unless more frequent deviation reporting is specified in the permit, any other deviation shall be documented in the semi-annual monitoring report and the annual compliance certification (see G4 and G5). 567 IAC 22.108(5)"b"

G16. Notification Requirements for Sources That Become Subject to NSPS and NESHAP Regulations During the term of this permit, the permittee must notify the department of any source that becomes subject to a standard or other requirement under 567-subrule 23.1(2) (standards of performance of new stationary sources) or section 111 of the Act; or 567-subrule 23.1(3) (emissions standards for hazardous air pollutants), 567-subrule 23.1(4) (emission standards for hazardous air pollutants for source categories) or section 112 of the Act. This notification shall be submitted in writing to the department pursuant to the notification requirements in 40 CFR Section 60.7, 40 CFR Section 61.07, and/or 40 CFR Section 63.9. 567 IAC 23.1(2), 567 IAC 23.1(3), 567 IAC 23.1(4)

G17. Requirements for Making Changes to Emission Sources That Do Not Require Title V Permit Modification

- 1. Off Permit Changes to a Source. Pursuant to section 502(b)(10) of the CAAA, the permittee may make changes to this installation/facility without revising this permit if:
 - a. The changes are not major modifications under any provision of any program required by section 110 of the Act, modifications under section 111 of the act, modifications under section 112 of the act, or major modifications as defined in 567 IAC Chapter 22.
 - b. The changes do not exceed the emissions allowable under the permit (whether expressed therein as a rate of emissions or in terms of total emissions);
 - c. The changes are not modifications under any provisions of Title I of the Act and the changes do not exceed the emissions allowable under the permit (whether expressed therein as a rate of emissions or as total emissions):
 - d. The changes are not subject to any requirement under Title IV of the Act (revisions affecting Title IV permitting are addressed in rules 567—22.140(455B) through 567 22.144(455B));.
 - e. The changes comply with all applicable requirements.
 - f. For each such change, the permitted source provides to the department and the administrator by certified mail, at least 30 days in advance of the proposed change, a written notification, including the following, which must be attached to the permit by the source, the department and the administrator:
 - i. A brief description of the change within the permitted facility,
 - ii. The date on which the change will occur,
 - iii. Any change in emission as a result of that change,
 - iv. The pollutants emitted subject to the emissions trade
 - v. If the emissions trading provisions of the state implementation plan are invoked, then Title V permit requirements with which the source shall comply; a description of how the emissions increases and decreases will comply with the terms and conditions of the Title V permit.
 - vi. A description of the trading of emissions increases and decreases for the purpose of complying with a federally enforceable emissions cap as specified in and in compliance with the Title V permit; and
 - vii. Any permit term or condition no longer applicable as a result of the change. $567 \, IAC \, 22.110(1)$

- 2. Such changes do not include changes that would violate applicable requirements or contravene federally enforceable permit terms and conditions that are monitoring (including test methods), record keeping, reporting, or compliance certification requirements. 567 IAC 22.110(2)
- 3. Notwithstanding any other part of this rule, the director may, upon review of a notice, require a stationary source to apply for a Title V permit if the change does not meet the requirements of subrule 22.110(1). 567 IAC 22.110(3)
- 4. The permit shield provided in subrule 22.108(18) shall not apply to any change made pursuant to this rule. Compliance with the permit requirements that the source will meet using the emissions trade shall be determined according to requirements of the state implementation plan authorizing the emissions trade. 567 IAC 22.110(4)
- 5. No permit revision shall be required, under any approved economic incentives, marketable permits, emissions trading and other similar programs or processes, for changes that are provided for in this permit. 567 IAC 22.108(11)

G18. Duty to Modify a Title V Permit

- 1. Administrative Amendment.
 - a. An administrative permit amendment is a permit revision that does any of the following:
 - i. Correct typographical errors
 - ii. Identify a change in the name, address, or telephone number of any person identified in the permit, or provides a similar minor administrative change at the source;
 - iii. Require more frequent monitoring or reporting by the permittee; or
 - iv. Allow for a change in ownership or operational control of a source where the director determines that no other change in the permit is necessary, provided that a written agreement containing a specific date for transfer of permit responsibility, coverage and liability between the current and new permittee has been submitted to the director.
 - b. The permittee may implement the changes addressed in the request for an administrative amendment immediately upon submittal of the request. The request shall be submitted to the director.
 - c. Administrative amendments to portions of permits containing provisions pursuant to Title IV of the Act shall be governed by regulations promulgated by the administrator under Title IV of the Act.
- 2. Minor Title V Permit Modification.
 - a. Minor Title V permit modification procedures may be used only for those permit modifications that satisfy all of the following:
 - i. Do not violate any applicable requirement;
 - ii. Do not involve significant changes to existing monitoring, reporting or recordkeeping requirements in the Title V permit;
 - iii. Do not require or change a case by case determination of an emission limitation or other standard, or an increment analysis;
 - iv. Do not seek to establish or change a permit term or condition for which there is no corresponding underlying applicable requirement and that the source has assumed in order to avoid an applicable requirement to which the source would otherwise be subject. Such terms and conditions include any federally enforceable emissions caps which the source would assume to avoid classification as a modification under any provision under Title I of the Act; and an alternative emissions limit approved pursuant to regulations promulgated under section 112(i)(5) of the Act;
 - v. Are not modifications under any provision of Title I of the Act; and
 - vi. Are not required to be processed as significant modification under rule 567 22.113(455B).
 - b. An application for minor permit revision shall be on the minor Title V modification application form and shall include at least the following:
 - i. A description of the change, the emissions resulting from the change, and any new applicable requirements that will apply if the change occurs;
 - ii. The permittee's suggested draft permit;
 - iii. Certification by a responsible official, pursuant to 567 IAC 22.107(4), that the proposed modification meets the criteria for use of minor permit modification procedures and a request that such procedures be used; and
 - iv. Completed forms to enable the department to notify the administrator and the affected states as required by 567 IAC 22.107(7).
 - c. The permittee may make the change proposed in its minor permit modification application immediately after it files the application. After the permittee makes this change and until the director takes any of the actions specified in 567 IAC 22.112(4) "a" to "c", the permittee must comply with both the applicable

requirements governing the change and the proposed permit terms and conditions. During this time, the permittee need not comply with the existing permit terms and conditions it seeks to modify. However, if the permittee fails to comply with its proposed permit terms and conditions during this time period, the existing permit terms and conditions it seeks to modify may be enforced against the facility.

3. Significant Title V Permit Modification.

Significant Title V modification procedures shall be used for applications requesting Title V permit modifications that do not qualify as minor Title V modifications or as administrative amendments. These include but are not limited to all significant changes in monitoring permit terms, every relaxation of reporting or recordkeeping permit terms, and any change in the method of measuring compliance with existing requirements. Significant Title V modifications shall meet all requirements of 567 IAC Chapter 22, including those for applications, public participation, review by affected states, and review by the administrator, as those requirements that apply to Title V issuance and renewal.

The permittee shall submit an application for a significant permit modification not later than three months after commencing operation of the changed source unless the existing Title V permit would prohibit such construction or change in operation, in which event the operation of the changed source may not commence until the department revises the permit. 567 IAC 22.111-567 IAC 22.113

G19. Duty to Obtain Construction Permits

Unless exempted in 567 IAC 22.1(2) or to meet the parameters established in 567 IAC 22.1(1)"c", the permittee shall not construct, install, reconstruct or alter any equipment, control equipment or anaerobic lagoon without first obtaining a construction permit, or conditional permit, or permit pursuant to rule 567 IAC 22.8, or permits required pursuant to rules 567 IAC 22.4, 567 IAC 22.5, 567 IAC 31.3, and 567 IAC 33.3 as required in 567 IAC 22.1(1). A permit shall be obtained prior to the initiation of construction, installation or alteration of any portion of the stationary source or anaerobic lagoon. 567 IAC 22.1(1)

G20. Asbestos

The permittee shall comply with 567 IAC 23.1(3)"a", and 567 IAC 23.2(3)"g" when activities involve asbestos mills, surfacing of roadways, manufacturing operations, fabricating, insulating, waste disposal, spraying applications, demolition and renovation operations (567 IAC 23.1(3)"a"); training fires and controlled burning of a demolished building (567 IAC 23.2).

G21. Open Burning

The permittee is prohibited from conducting open burning, except as provided in 567 IAC 23.2. 567 IAC 23.2 <u>except</u> 23.2(3)"j"; 567 IAC 23.2(3)"j" - State Only

G22. Acid Rain (Title IV) Emissions Allowances

The permittee shall not exceed any allowances that it holds under Title IV of the Act or the regulations promulgated there under. Annual emissions of sulfur dioxide in excess of the number of allowances to emit sulfur dioxide held by the owners and operators of the unit or the designated representative of the owners and operators is prohibited. Exceedences of applicable emission rates are prohibited. "Held" in this context refers to both those allowances assigned to the owners and operators by USEPA, and those allowances supplementally acquired by the owners and operators. The use of any allowance prior to the year for which it was allocated is prohibited. Contravention of any other provision of the permit is prohibited. 567 IAC 22.108(7)

G23. Stratospheric Ozone and Climate Protection (Title VI) Requirements

- 1. The permittee shall comply with the standards for labeling of products using ozone-depleting substances pursuant to 40 CFR Part 82, Subpart E:
 - a. All containers in which a class I or class II substance is stored or transported, all products containing a class I substance, and all products directly manufactured with a class I substance must bear the required warning statement if it is being introduced into interstate commerce pursuant to § 82.106.
 - b. The placement of the required warning statement must comply with the requirements pursuant to § 82.108.
 - c. The form of the label bearing the required warning statement must comply with the requirements pursuant to § 82.110.
 - d. No person may modify, remove, or interfere with the required warning statement except as described in § 82.112.
- 2. The permittee shall comply with the standards for recycling and emissions reduction pursuant to 40 CFR Part 82, Subpart F, except as provided for MVACs in Subpart B:
 - a. Persons opening appliances for maintenance, service, repair, or disposal must comply with the required practices pursuant to § 82.156.
 - b. Equipment used during the maintenance, service, repair, or disposal of appliances must comply with the

standards for recycling and recovery equipment pursuant to § 82.158.

- c. Persons performing maintenance, service, repair, or disposal of appliances must be certified by an approved technician certification program pursuant to § 82.161.
- d. Persons disposing of small appliances, MVACs, and MVAC-like appliances must comply with reporting and recordkeeping requirements pursuant to § 82.166. ("MVAC-like appliance" as defined at § 82.152)
- e. Persons owning commercial or industrial process refrigeration equipment must comply with the leak repair requirements pursuant to § 82.156.
- f. Owners/operators of appliances normally containing 50 or more pounds of refrigerant must keep records of refrigerant purchased and added to such appliances pursuant to § 82.166.
- 3. If the permittee manufactures, transforms, imports, or exports a class I or class II substance, the permittee is subject to all the requirements as specified in 40 CFR part 82, Subpart A, Production and Consumption Controls.
- 4. If the permittee performs a service on motor (fleet) vehicles when this service involves ozone-depleting substance refrigerant (or regulated substitute substance) in the motor vehicle air conditioner (MVAC), the permittee is subject to all the applicable requirements as specified in 40 CFR part 82, Subpart B, Servicing of Motor Vehicle Air Conditioners. The term "motor vehicle" as used in Subpart B does not include a vehicle in which final assembly of the vehicle has not been completed. The term "MVAC" as used in Subpart B does not include the air-tight sealed refrigeration system used as refrigerated cargo, or system used on passenger buses using HCFC-22 refrigerant,

 5. The permittee shall be allowed to switch from any ozone-depleting substance to any alternative that is listed in the
- 5. The permittee shall be allowed to switch from any ozone-depleting substance to any alternative that is listed in the Significant New Alternatives Program (SNAP) promulgated pursuant to 40 CFR part 82, Subpart G, Significant New Alternatives Policy Program. 40 CFR part 82

G24. Permit Reopenings

- 1. This permit may be modified, revoked, reopened, and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition. 567 IAC 22.108(9)"c"
- 2. Additional applicable requirements under the Act become applicable to a major part 70 source with a remaining permit term of 3 or more years. Revisions shall be made as expeditiously as practicable, but not later than 18 months after the promulgation of such standards and regulations.
 - a. Reopening and revision on this ground is <u>not</u> required if the permit has a remaining term of less than three years;
 - b. Reopening and revision on this ground is <u>not</u> required if the effective date of the requirement is later than the date on which the permit is due to expire, unless the original permit or any of its terms and conditions have been extended pursuant to 40 CFR 70.4(b)(10)(i) or (ii) as amended to May 15, 2001.
 - c. Reopening and revision on this ground is <u>not</u> required if the additional applicable requirements are implemented in a general permit that is applicable to the source and the source receives approval for coverage under that general permit. 567 IAC 22.108(17)"a", 567 IAC 22.108(17)"b"
- 3. A permit shall be reopened and revised under any of the following circumstances:
 - a. The department receives notice that the administrator has granted a petition for disapproval of a permit pursuant to 40 CFR 70.8(d) as amended to July 21, 1992, provided that the reopening may be stayed pending judicial review of that determination;
 - b. The department or the administrator determines that the Title V permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of the Title V permit;
 - c. Additional applicable requirements under the Act become applicable to a Title V source, provided that the reopening on this ground is not required if the permit has a remaining term of less than three years, the effective date of the requirement is later than the date on which the permit is due to expire, or the additional applicable requirements are implemented in a general permit that is applicable to the source and the source receives approval for coverage under that general permit. Such a reopening shall be complete not later than 18 months after promulgation of the applicable requirement.
 - d. Additional requirements, including excess emissions requirements, become applicable to a Title IV affected source under the acid rain program. Upon approval by the administrator, excess emissions offset plans shall be deemed to be incorporated into the permit.
 - e. The department or the administrator determines that the permit must be revised or revoked to ensure compliance by the source with the applicable requirements. 567 IAC 22.114(1)
- 4. Proceedings to reopen and reissue a Title V permit shall follow the procedures applicable to initial permit issuance and shall effect only those parts of the permit for which cause to reopen exists. 567 IAC 22.114(2)

- 5. A notice of intent shall be provided to the Title V source at least 30 days in advance of the date the permit is to be reopened, except that the director may provide a shorter time period in the case of an emergency. 567 IAC 22.114(3) **G25. Permit Shield**
- 1. The director may expressly include in a Title V permit a provision stating that compliance with the conditions of

the permit shall be deemed compliance with any applicable requirements as of the date of permit issuance, provided that:

- a. Such applicable requirements are included and are specifically identified in the permit; or
 - b. The director, in acting on the permit application or revision, determines in writing that other requirements specifically identified are not applicable to the source, and the permit includes the determination or a concise summary thereof.
- 2. A Title V permit that does not expressly state that a permit shield exists shall be presumed not to provide such a shield
- 3. A permit shield shall not alter or affect the following:
 - a. The provisions of Section 303 of the Act (emergency orders), including the authority of the administrator under that section:
 - b. The liability of an owner or operator of a source for any violation of applicable requirements prior to or at the time of permit issuance;
 - c. The applicable requirements of the acid rain program, consistent with Section 408(a) of the Act;
 - d. The ability of the department or the administrator to obtain information from the facility pursuant to Section 114 of the Act. 567 IAC 22.108 (18)

G26. Severability

The provisions of this permit are severable and if any provision or application of any provision is found to be invalid by this department or a court of law, the application of such provision to other circumstances, and the remainder of this permit, shall not be affected by such finding. 567 IAC 22.108 (8)

G27. Property Rights

The permit does not convey any property rights of any sort, or any exclusive privilege. 567 IAC 22.108 (9)"d"

G28. Transferability

This permit is not transferable from one source to another. If title to the facility or any part of it is transferred, an administrative amendment to the permit must be sought consistent with the requirements of 567 IAC 22.111(1). 567 IAC 22.111(1)"d"

G29. Disclaimer

No review has been undertaken on the engineering aspects of the equipment or control equipment other than the potential of that equipment for reducing air contaminant emissions. 567 IAC 22.3(3)"c"

G30. Notification and Reporting Requirements for Stack Tests or Monitor Certification

The permittee shall notify the department's stack test contact in writing not less than 30 days before a required test or performance evaluation of a continuous emission monitor is performed to determine compliance with applicable requirements of 567 – Chapter 23 or a permit condition. Such notice shall include the time, the place, the name of the person who will conduct the test and other information as required by the department. If the owner or operator does not provide timely notice to the department, the department shall not consider the test results or performance evaluation results to be a valid demonstration of compliance with applicable rules or permit conditions. Upon written request, the department may allow a notification period of less than 30 days. At the department's request, a pretest meeting shall be held not later than 15 days prior to conducting the compliance demonstration. A testing protocol shall be submitted to the department no later than 15 days before the owner or operator conducts the compliance demonstration. A representative of the department shall be permitted to witness the tests. Results of the tests shall be submitted in writing to the department's stack test contact in the form of a comprehensive report within six weeks of the completion of the testing. Compliance tests conducted pursuant to this permit shall be conducted with the source operating in a normal manner at its maximum continuous output as rated by the equipment manufacturer, or the rate specified by the owner as the maximum production rate at which the source shall be operated. In cases where compliance is to be demonstrated at less than the maximum continuous output as rated by the equipment manufacturer, and it is the owner's intent to limit the capacity to that rating, the owner may submit evidence to the department that the source has been physically altered so that capacity cannot be exceeded, or the

department may require additional testing, continuous monitoring, reports of operating levels, or any other information deemed necessary by the department to determine whether such source is in compliance. Stack test notifications, reports and correspondence shall be sent to:

Stack Test Review Coordinator Iowa DNR, Air Quality Bureau 7900 Hickman Road, Suite #1 Windsor Heights, IA 50324 (515) 725-9545

Within Polk and Linn Counties, stack test notifications, reports and correspondence shall also be directed to the supervisor of the respective county air pollution program. 567 IAC 25.1(7)"a", 567 IAC 25.1(9)

G31. Prevention of Air Pollution Emergency Episodes

The permittee shall comply with the provisions of 567 IAC Chapter 26 in the prevention of excessive build-up of air contaminants during air pollution episodes, thereby preventing the occurrence of an emergency due to the effects of these contaminants on the health of persons. 567 IAC 26.1(1)

G32. Contacts List

The current address and phone number for reports and notifications to the EPA administrator is:

Chief of Air Permits U.S. EPA Region 7 Air Permits and Compliance Branch 11201 Renner Blvd. Lenexa, KS 66219 (913) 551-7020

The current address and phone number for reports and notifications to the department or the Director is:

Chief, Air Quality Bureau Iowa Department of Natural Resources 7900 Hickman Road, Suite #1 Windsor Heights, IA 50324 (515) 725-9500

Reports or notifications to the DNR Field Offices or local programs shall be directed to the supervisor at the appropriate field office or local program. Current addresses and phone numbers are:

Field Office 1

909 West Main – Suite 4 Manchester, IA 52057 (563) 927-2640

Field Office 3

1900 N. Grand Ave. Spencer, IA 51301 (712) 262-4177

Field Office 5

7900 Hickman Road, Suite #200 Windsor Heights, IA 50324 (515) 725-0268

Polk County Public Works Dept.

Air Quality Division 5885 NE 14th St. Des Moines, IA 50313 (515) 286-3351

Field Office 2

2300-15th St., SW Mason City, IA 50401 (641) 424-4073

Field Office 4

1401 Sunnyside Lane Atlantic, IA 50022 (712) 243-1934

Field Office 6

1023 West Madison Street Washington, IA 52353-1623 (319) 653-2135

Linn County Public Health

Air Quality Branch 501 13th St., NW Cedar Rapids, IA 52405 (319) 892-6000

Appendices:

A. 40 CFR 63 Subpart Subpart ZZZZ—National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines.

http://www.ecfr.gov/cgi-bin/text-

<u>idx?c=ecfr;rgn=div6;view=text;node=40%3A14.0.1.1.1.1;idno=40;sid=e94dcf</u>de4a04b27290c445a56e635e58;cc=ecfr

B. 40 CFR 60 Subpart Kb—Standards of Performance for Volatile Organic Liquid Storage Vessels (Including Petroleum Liquid Storage Vessels) for Which Construction, Reconstruction, or Modification Commenced After July 23, 1984.

http://www.ecfr.gov/cgi-

 $\frac{bin/retrieveECFR?gp=\&SID=29edb45db54e10f9b668c4202ab83968\&mc=tru}{e\&n=pt40.7.60\&r=PART\&ty=HTML}$

C. Cross-State Air Pollution Rule (CSAPR) a.k.a Transport Rule (TR) Trading Program Title V Requirements (See next page)

Cross-State Air Pollution Rule (CSAPR) a.k.a Transport Rule (TR) Trading Program Title V Requirements

Description of TR Monitoring Provisions

The TR subject unit(s), and the unit-specific monitoring provisions at this source, are identified in the following table(s). These unit(s) are subject to the requirements for the TR NO_x Annual Trading Program, TR NO_x Ozone Season Trading Program and TR SO₂ Group 1 Trading Program.

Unit ID: 1 (ORIS Code: 56230)							
North Centerville Combustion Turbines, Interstate Power and Light (Alliant Energy)							
Parameter	Continuous emission monitoring system or systems (CEMS) requirements pursuant to 40 CFR part 75, subpart B (for SO ₂ monitoring) and 40 CFR part 75, subpart H (for NO _x monitoring)	Excepted monitoring system requirements for gas- and oil- fired units pursuant to 40 CFR part 75, appendix D	Excepted monitoring system requirements for gas- and oil-fired peaking units pursuant to 40 CFR part 75, appendix E	Low Mass Emissions excepted monitoring (LME) requirements for gas- and oil-fired units pursuant to 40 CFR 75.19	EPA-approved alternative monitoring system requirements pursuant to 40 CFR part 75, subpart E		
SO ₂				X			
NOx				X			
Heat input				X			

Unit ID: 2 (ORIS Code: 56230)							
North Centerville Combustion Turbines, Interstate Power and Light (Alliant Energy)							
Parameter	Continuous emission monitoring system or systems (CEMS) requirements pursuant to 40 CFR part 75, subpart B (for SO ₂ monitoring) and 40 CFR part 75, subpart H (for NO _x monitoring)	Excepted monitoring system requirements for gas- and oil- fired units pursuant to 40 CFR part 75, appendix D	Excepted monitoring system requirements for gas- and oil-fired peaking units pursuant to 40 CFR part 75, appendix E	Low Mass Emissions excepted monitoring (LME) requirements for gas- and oil-fired units pursuant to 40 CFR 75.19	EPA-approved alternative monitoring system requirements pursuant to 40 CFR part 75, subpart E		
SO_2				X			
NO _x				X			
Heat input				X			

- 1. The above description of the monitoring used by a unit does not change, create an exemption from, or otherwise affect the monitoring, recordkeeping, and reporting requirements applicable to the unit under 40 CFR 97.430 through 97.435 (TR NO_x Annual Trading Program), 97.530 through 97.535 (TR NO_x Ozone Season Trading Program), and 97.630 through 97.635 (TR SO₂ Group 1 Trading Program). The monitoring, recordkeeping and reporting requirements applicable to each unit are included below in the standard conditions for the applicable TR trading programs.
- 2. Owners and operators must submit to the Administrator a monitoring plan for each unit in accordance with 40 CFR 75.53, 75.62 and 75.73, as applicable. The monitoring plan for each unit is available at the EPA's website at http://www.epa.gov/airmarkets/emissions/monitoringplans.html.
- 3. Owners and operators that want to use an alternative monitoring system must submit to the Administrator a petition requesting approval of the alternative monitoring system in accordance with 40 CFR part 75, subpart E and 40 CFR 75.66 and 97.435 (TR NO_x Annual Trading Program), 97.535 (TR NO_x Ozone Season Trading Program) and/or 97.635 (TR SO₂ Group 1 Trading Program). The Administrator's response approving or disapproving any petition for an alternative monitoring system is available on the EPA's website at http://www.epa.gov/airmarkets/emissions/petitions.html.
- 4. Owners and operators that want to use an alternative to any monitoring, recordkeeping, or reporting requirement under 40 CFR 97.430 through 97.434 (TR NO_x Annual Trading Program), 97.530 through 97.534 (TR NO_x Ozone Season Trading Program) and/or 97.630 through 97.634 (TR SO₂ Group 1 Trading Program) must submit to the Administrator a petition requesting approval of the alternative in accordance with 40 CFR 75.66 and 97.435 (TR NO_x Annual Trading Program), 97.535 (TR NO_x Ozone Season Trading Program) and/or 97.635 (TR SO₂ Group 1 Trading Program). The Administrator's response approving or disapproving any petition for an alternative to a monitoring, recordkeeping, or reporting requirement is available on EPA's website at http://www.epa.gov/airmarkets/emissions/petitions.html.
- 5. The descriptions of monitoring applicable to the unit included above meet the requirement of 40 CFR 97.430 through 97.434 (TR NO_x Annual Trading Program), 97.530 through 97.534 (TR NO_x Ozone Season Trading Program) and 97.630 through 97.634 (TR SO₂ Group 1 Trading Program), and therefore minor permit modification procedures, in accordance with 40 CFR 70.7(e)(2)(i)(B) or 71.7(e)(1)(i)(B), may be used to add to or change this unit's monitoring system description.

TR NO_x Annual Trading Program requirements (40 CFR 97.406)

a. Designated representative requirements.

The owners and operators shall comply with the requirement to have a designated representative, and may have an alternate designated representative, in accordance with 40 CFR 97.413 through 97.418.

b. Emissions monitoring, reporting, and recordkeeping requirements.

1. The owners and operators, and the designated representative, of each TR NO_x Annual source and each TR NO_x Annual unit at the source shall comply with the monitoring,

reporting, and recordkeeping requirements of 40 CFR 97.430 (general requirements, including installation, certification, and data accounting, compliance deadlines, reporting data, prohibitions, and long-term cold storage), 97.431 (initial monitoring system certification and recertification procedures), 97.432 (monitoring system out-of-control periods), 97.433 (notifications concerning monitoring), 97.434 (recordkeeping and reporting, including monitoring plans, certification applications, quarterly reports, and compliance certification), and 97.435 (petitions for alternatives to monitoring, recordkeeping, or reporting requirements).

2. The emissions data determined in accordance with 40 CFR 97.430 through 97.435 shall be used to calculate allocations of TR NO_x Annual allowances under 40 CFR 97.411(a)(2) and (b) and 97.412 and to determine compliance with the TR NO_x Annual emissions limitation and assurance provisions under paragraph (c) below, provided that, for each monitoring location from which mass emissions are reported, the mass emissions amount used in calculating such allocations and determining such compliance shall be the mass emissions amount for the monitoring location determined in accordance with 40 CFR 97.430 through 97.435 and rounded to the nearest ton, with any fraction of a ton less than 0.50 being deemed to be zero.

c. NO_x emissions requirements.

- 1. TR NO_x Annual emissions limitation.
- i. As of the allowance transfer deadline for a control period in a given year, the owners and operators of each TR NO_x Annual source and each TR NO_x Annual unit at the source shall hold, in the source's compliance account, TR NO_x Annual allowances available for deduction for such control period under 40 CFR 97.424(a) in an amount not less than the tons of total NO_x emissions for such control period from all TR NO_x Annual units at the source.
- ii. If total NO_x emissions during a control period in a given year from the TR NO_x Annual units at a TR NO_x Annual source are in excess of the TR NO_x Annual emissions limitation set forth in paragraph (c)(1)(i) above, then:
 - A. The owners and operators of the source and each TR NO_x Annual unit at the source shall hold the TR NO_x Annual allowances required for deduction under 40 CFR 97.424(d); and
 - B. The owners and operators of the source and each TR NO_x Annual unit at the source shall pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act, and each ton of such excess emissions and each day of such control period shall constitute a separate violation of 40 CFR part 97, subpart AAAAA and the Clean Air Act.
 - 2. TR NO_x Annual assurance provisions.

units at TR NO_x Annual sources in the state exceed the state assurance level, then the owners and operators of such sources and units in each group of one or more sources and units having a common designated representative for such control period, where the common designated representative's share of such NO_x emissions during such control period exceeds the common designated representative's assurance level for the state and such control period, shall hold (in the assurance account established for the owners and operators of such group) TR NO_x Annual allowances available for deduction for such control period under 40 CFR 97.425(a) in an amount equal to two times the product (rounded to the nearest whole number), as determined by the Administrator in accordance with 40 CFR 97.425(b), of multiplying— (A) The quotient of the amount by which the common designated representative's share of such NO_x emissions exceeds

the common designated representative's assurance level divided by the sum of the amounts, determined for all common designated representatives for such sources and units in the state for such control period, by which each common designated representative's share of such NO_x emissions exceeds the respective common designated representative's assurance level; and (B) The amount by which total NO_x emissions from all TR NO_x Annual units at TR NO_x Annual sources in the state for such control period exceed the state assurance level.

- i. The owners and operators shall hold the TR NO_x Annual allowances required under paragraph (c)(2)(i) above, as of midnight of November 1 (if it is a business day), or midnight of the first business day thereafter (if November 1 is not a business day), immediately after such control period.
- ii. Total NO_x emissions from all TR NO_x Annual units at TR NO_x Annual sources in the State during a control period in a given year exceed the state assurance level if such total NO_x emissions exceed the sum, for such control period, of the state NO_x Annual trading budget under 40 CFR 97.410(a) and the state's variability limit under 40 CFR 97.410(b).
- iii. It shall not be a violation of 40 CFR part 97, subpart AAAAA or of the Clean Air Act if total NO_x emissions from all TR NO_x Annual units at TR NO_x Annual sources in the State during a control period exceed the state assurance level or if a common designated representative's share of total NO_x emissions from the TR NO_x Annual units at TR NO_x Annual sources in the state during a control period exceeds the common designated representative's assurance level.
- iv. To the extent the owners and operators fail to hold TR NO_x Annual allowances for a control period in a given year in accordance with paragraphs (c)(2)(i) through (iii) above,
 - . The owners and operators shall pay any fine, penalty, or assessment or comply with any other remedy imposed under the Clean Air Act; and
 - A. Each TR NO_x Annual allowance that the owners and operators fail to hold for such control period in accordance with paragraphs (c)(2)(i) through (iii) above and each day of such control period shall constitute a separate violation of 40 CFR part 97, subpart AAAAA and the Clean Air Act.
 - 3. Compliance periods.
 - A TR NO_x Annual unit shall be subject to the requirements under paragraph (c)(1) above for the control period starting on the later of January 1, 2015, or the deadline for meeting the unit's monitor certification requirements under 40 CFR 97.430(b) and for each control period thereafter.
 - i. A TR NO_x Annual unit shall be subject to the requirements under paragraph (c)(2) above for the control period starting on the later of January 1, 2017 or the deadline for meeting the unit's monitor certification requirements under 40 CFR 97.430(b) and for each control period thereafter.
 - 4. Vintage of allowances held for compliance.
 - . A TR NO_x Annual allowance held for compliance with the requirements under paragraph (c)(1)(i) above for a control period in a given year must be a TR NO_x Annual allowance that was allocated for such control period or a control period in a prior year.
 - i. A TR NO_x Annual allowance held for compliance with the requirements under paragraphs (c)(1)(ii)(A) and (2)(i) through (iii) above for a control period in a given year must be a TR NO_x Annual allowance that was allocated for a control period in a prior year or the control period in the given year or in the immediately following year.

- 5. Allowance Management System requirements. Each TR NO_x Annual allowance shall be held in, deducted from, or transferred into, out of, or between Allowance Management System accounts in accordTrance with 40 CFR part 97, subpart AAAAA.
- 6. Limited authorization. A TR NO_x Annual allowance is a limited authorization to emit one ton of NO_x during the control period in one year. Such authorization is limited in its use and duration as follows:
- . Such authorization shall only be used in accordance with the TR NO_x Annual Trading Program; and
- i. Notwithstanding any other provision of 40 CFR part 97, the Administrator has the authority to terminate or limit the use and duration of such authorization to the extent the Administrator determines is necessary or appropriate to implement any provision of the Clean Air Act.
 - 7. Property right. A TR NO_x Annual allowance does not constitute a property right.

d. Title V permit revision requirements.

- 1. No title V permit revision shall be required for any allocation, holding, deduction, or transfer of TR NO_x Annual allowances in accordance with 40 CFR part 97, subpart AAAAA.
- 2. This permit incorporates the TR emissions monitoring, recordkeeping and reporting requirements pursuant to 40 CFR 97.430 through 97.435, and the requirements for a continuous emission monitoring system (pursuant to 40 CFR part 75, subparts B and H), an excepted monitoring system (pursuant to 40 CFR part 75, appendices D and E), a low mass emissions excepted monitoring methodology (pursuant to 40 CFR 75.19), and an alternative monitoring system (pursuant to 40 CFR part 75, subpart E). Therefore, the Description of TR Monitoring Provisions table for units identified in this permit may be added to, or changed, in this title V permit using minor permit modification procedures in accordance with 40 CFR 97.406(d)(2) and 70.7(e)(2)(i)(B) or 71.7(e)(1)(i)(B).

e. Additional recordkeeping and reporting requirements.

- 1. Unless otherwise provided, the owners and operators of each TR NO_x Annual source and each TR NO_x Annual unit at the source shall keep on site at the source each of the following documents (in hardcopy or electronic format) for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the Administrator.
- i. The certificate of representation under 40 CFR 97.416 for the designated representative for the source and each TR NO_x Annual unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such certificate of representation and documents are superseded because of the submission of a new certificate of representation under 40 CFR 97.416 changing the designated representative.
- ii. All emissions monitoring information, in accordance with 40 CFR part 97, subpart AAAAA.
- iii. Copies of all reports, compliance certifications, and other submissions and all records made or required under, or to demonstrate compliance with the requirements of, the TR NO_x Annual Trading Program.
 - 2. The designated representative of a TR NO_x Annual source and each TR NO_x Annual unit at the source shall make all submissions required under the TR NO_x Annual Trading Program, except as provided in 40 CFR 97.418. This requirement does not change, create

an exemption from, or otherwise affect the responsible official submission requirements under a title V operating permit program in 40 CFR parts 70 and 71.

f. Liability.

- 1. Any provision of the TR NO_x Annual Trading Program that applies to a TR NO_x Annual source or the designated representative of a TR NO_x Annual source shall also apply to the owners and operators of such source and of the TR NO_x Annual units at the source.
- 2. Any provision of the TR NO_x Annual Trading Program that applies to a TR NO_x Annual unit or the designated representative of a TR NO_x Annual unit shall also apply to the owners and operators of such unit.

g. Effect on other authorities.

No provision of the TR NO_x Annual Trading Program or exemption under 40 CFR 97.405 shall be construed as exempting or excluding the owners and operators, and the designated representative, of a TR NO_x Annual source or TR NO_x Annual unit from compliance with any other provision of the applicable, approved state implementation plan, a federally enforceable permit, or the Clean Air Act.

TR NO_x Ozone Season Trading Program Requirements (40 CFR 97.506)

a. Designated representative requirements.

The owners and operators shall comply with the requirement to have a designated representative, and may have an alternate designated representative, in accordance with 40 CFR 97.513 through 97.518.

b. Emissions monitoring, reporting, and recordkeeping requirements.

- 1. The owners and operators, and the designated representative, of each TR NO_x Ozone Season source and each TR NO_x Ozone Season unit at the source shall comply with the monitoring, reporting, and recordkeeping requirements of 40 CFR 97.530 (general requirements, including installation, certification, and data accounting, compliance deadlines, reporting data, prohibitions, and long-term cold storage), 97.531 (initial monitoring system certification and recertification procedures), 97.532 (monitoring system out-of-control periods), 97.533 (notifications concerning monitoring), 97.534 (recordkeeping and reporting, including monitoring plans, certification applications, quarterly reports, and compliance certification), and 97.535 (petitions for alternatives to monitoring, recordkeeping, or reporting requirements).
- 2. The emissions data determined in accordance with 40 CFR 97.530 through 97.535 shall be used to calculate allocations of TR NO_x Ozone Season allowances under 40 CFR 97.511(a)(2) and (b) and 97.512 and to determine compliance with the TR NO_x Ozone Season emissions limitation and assurance provisions under paragraph (c) below, provided that, for each monitoring location from which mass emissions are reported, the mass emissions amount used in calculating such allocations and determining such compliance shall be the mass emissions amount for the monitoring location determined in accordance with 40 CFR 97.530 through 97.535 and rounded to the nearest ton, with any fraction of a ton less than 0.50 being deemed to be zero.

c. NO_x emissions requirements.

- 1. TR NO_x Ozone Season emissions limitation.
- i. As of the allowance transfer deadline for a control period in a given year, the owners and operators of each TR NO_x Ozone Season source and each TR NO_x Ozone Season unit at the source shall hold, in the source's compliance account, TR NO_x Ozone Season allowances available for deduction for such control period under 40 CFR 97.524(a) in an amount not less

than the tons of total NO_x emissions for such control period from all TR NO_x Ozone Season units at the source.

- ii. If total NO_x emissions during a control period in a given year from the TR NO_x Ozone Season units at a TR NO_x Ozone Season source are in excess of the TR NO_x Ozone Season emissions limitation set forth in paragraph (c)(1)(i) above, then:
 - A. The owners and operators of the source and each TR NO_x Ozone Season unit at the source shall hold the TR NO_x Ozone Season allowances required for deduction under 40 CFR 97.524(d); and
 - B. The owners and operators of the source and each TR NO_x Ozone Season unit at the source shall pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act, and each ton of such excess emissions and each day of such control period shall constitute a separate violation of 40 CFR part 97, subpart BBBBB and the Clean Air Act.
 - 2. TR NO_x Ozone Season assurance provisions.
 - Season units at TR NO_x Ozone Season sources in the state exceed the state assurance level, then the owners and operators of such sources and units in each group of one or more sources and units having a common designated representative for such control period, where the common designated representative's share of such NO_x emissions during such control period exceeds the common designated representative's assurance level for the state and such control period, shall hold (in the assurance account established for the owners and operators of such group) TR NO_x Ozone Season allowances available for deduction for such control period under 40 CFR 97.525(a) in an amount equal to two times the product (rounded to the nearest whole number), as determined by the Administrator in accordance with 40 CFR 97.525(b), of multiplying—
 - The quotient of the amount by which the common designated representative's share of such NO_x emissions exceeds the common designated representative's assurance level divided by the sum of the amounts, determined for all common designated representatives for such sources and units in the state for such control period, by which each common designated representative's share of such NO_x emissions exceeds the respective common designated representative's assurance level; and
 - A. The amount by which total NO_x emissions from all TR NO_x Ozone Season units at TR NO_x Ozone Season sources in the state for such control period exceed the state assurance level.
- i. The owners and operators shall hold the TR NO_x Ozone Season allowances required under paragraph (c)(2)(i) above, as of midnight of November 1 (if it is a business day), or midnight of the first business day thereafter (if November 1 is not a business day), immediately after such control period.
- ii. Total NO_x emissions from all TR NO_x Ozone Season units at TR NO_xOzone Season sources in the state during a control period in a given year exceed the state assurance level if such total NO_x emissions exceed the sum, for such control period, of the State NO_x Ozone Season trading budget under 40 CFR 97.510(a) and the state's variability limit under 40 CFR 97.510(b).
- iii. It shall not be a violation of 40 CFR part 97, subpart BBBBB or of the Clean Air Act if total NO_x emissions from all TR NO_x Ozone Season units at TR NO_x Ozone Season sources in the state during a control period exceed the state assurance level or if a common designated representative's share of total NO_x emissions from the TR NO_x Ozone Season units at TR NO_x

Ozone Season sources in the state during a control period exceeds the common designated representative's assurance level.

- iv. To the extent the owners and operators fail to hold TR NO_x Ozone Season allowances for a control period in a given year in accordance with paragraphs (c)(2)(i) through (iii) above,
 - . The owners and operators shall pay any fine, penalty, or assessment or comply with any other remedy imposed under the Clean Air Act; and
 - A. Each TR NO_x Ozone Season allowance that the owners and operators fail to hold for such control period in accordance with paragraphs (c)(2)(i) through (iii) above and each day of such control period shall constitute a separate violation of 40 CFR part 97, subpart BBBBB and the Clean Air Act.
 - 3. Compliance periods.
 - . A TR NO_x Ozone Season unit shall be subject to the requirements under paragraph (c)(1) above for the control period starting on the later of May 1, 2015 or the deadline for meeting the unit's monitor certification requirements under 40 CFR 97.530(b) and for each control period thereafter.
- i. A TR NO_x Ozone Season unit shall be subject to the requirements under paragraph (c)(2) above for the control period starting on the later of May 1, 2017 or the deadline for meeting the unit's monitor certification requirements under 40 CFR 97.530(b) and for each control period thereafter.
 - 4. Vintage of allowances held for compliance.
- . A TR NO_x Ozone Season allowance held for compliance with the requirements under paragraph (c)(1)(i) above for a control period in a given year must be a TR NO_x Ozone Season allowance that was allocated for such control period or a control period in a prior year.
- i. A TR NO_x Ozone Season allowance held for compliance with the requirements under paragraphs (c)(1)(ii)(A) and (2)(i) through (iii) above for a control period in a given year must be a TR NO_x Ozone Season allowance that was allocated for a control period in a prior year or the control period in the given year or in the immediately following year.
 - 5. Allowance Management System requirements. Each TR NO_x Ozone Season allowance shall be held in, deducted from, or transferred into, out of, or between Allowance Management System accounts in accordance with 40 CFR part 97, subpart BBBBB.
 - 6. Limited authorization. A TR NO_x Ozone Season allowance is a limited authorization to emit one ton of NO_x during the control period in one year. Such authorization is limited in its use and duration as follows:
- . Such authorization shall only be used in accordance with the TR NO_x Ozone Season Trading Program; and
- i. Notwithstanding any other provision of 40 CFR part 97, subpart BBBBB, the Administrator has the authority to terminate or limit the use and duration of such authorization to the extent the Administrator determines is necessary or appropriate to implement any provision of the Clean Air Act.
 - 7. Property right. A TR NO_x Ozone Season allowance does not constitute a property right.

d. Title V permit revision requirements.

- 1. No title V permit revision shall be required for any allocation, holding, deduction, or transfer of TR NO_x Ozone Season allowances in accordance with 40 CFR part 97, subpart BBBBB.
- 2. This permit incorporates the TR emissions monitoring, recordkeeping and reporting requirements pursuant to 40 CFR 97.530 through 97.535, and the requirements for a

continuous emission monitoring system (pursuant to 40 CFR part 75, subparts B and H), an excepted monitoring system (pursuant to 40 CFR part 75, appendices D and E), a low mass emissions excepted monitoring methodology (pursuant to 40 CFR 75.19), and an alternative monitoring system (pursuant to 40 CFR part 75, subpart E). Therefore, the Description of TR Monitoring Provisions table for units identified in this permit may be added to, or changed, in this title V permit using minor permit modification procedures in accordance with 40 CFR 97.506(d)(2) and 70.7(e)(2)(i)(B) or 71.7(e)(1)(i)(B).

e. Additional recordkeeping and reporting requirements.

- 1. Unless otherwise provided, the owners and operators of each TR NO_x Ozone Season source and each TR NO_x Ozone Season unit at the source shall keep on site at the source each of the following documents (in hardcopy or electronic format) for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the Administrator.
- i. The certificate of representation under 40 CFR 97.516 for the designated representative for the source and each TR NO_x Ozone Season unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such certificate of representation and documents are superseded because of the submission of a new certificate of representation under 40 CFR 97.516 changing the designated representative.
- ii. All emissions monitoring information, in accordance with 40 CFR part 97, subpart BBBBB.
- iii. Copies of all reports, compliance certifications, and other submissions and all records made or required under, or to demonstrate compliance with the requirements of, the TR NO_x Ozone Season Trading Program.
 - 2. The designated representative of a TR NO_x Ozone Season source and each TR NO_x Ozone Season unit at the source shall make all submissions required under the TR NO_x Ozone Season Trading Program, except as provided in 40 CFR 97.518. This requirement does not change, create an exemption from, or otherwise affect the responsible official submission requirements under a title V operating permit program in 40 CFR parts 70 and 71.

f. Liability.

- 1. Any provision of the TR NO_x Ozone Season Trading Program that applies to a TR NO_x Ozone Season source or the designated representative of a TR NO_x Ozone Season source shall also apply to the owners and operators of such source and of the TR NO_x Ozone Season units at the source.
- 2. Any provision of the TR NO_x Ozone Season Trading Program that applies to a TR NO_x Ozone Season unit or the designated representative of a TR NO_x Ozone Season unit shall also apply to the owners and operators of such unit.

g. Effect on other authorities.

No provision of the TR NO_x Ozone Season Trading Program or exemption under 40 CFR 97.505 shall be construed as exempting or excluding the owners and operators, and the designated representative, of a TR NO_x Ozone Season source or TR NO_x Ozone Season unit from compliance with any other provision of the applicable, approved state implementation plan, a federally enforceable permit, or the Clean Air Act.

TR SO₂ Group 1 Trading Program requirements (40 CFR 97.606)

a. Designated representative requirements.

The owners and operators shall comply with the requirement to have a designated representative, and may have an alternate designated representative, in accordance with 40 CFR 97.613 through 97.618.

b. Emissions monitoring, reporting, and recordkeeping requirements.

- 1. The owners and operators, and the designated representative, of each TR SO₂ Group 1 source and each TR SO₂ Group 1 unit at the source shall comply with the monitoring, reporting, and recordkeeping requirements of 40 CFR 97.630 (general requirements, including installation, certification, and data accounting, compliance deadlines, reporting data, prohibitions, and long-term cold storage), 97.631 (initial monitoring system certification and recertification procedures), 97.632 (monitoring system out-of-control periods), 97.633 (notifications concerning monitoring), 97.634 (recordkeeping and reporting, including monitoring plans, certification applications, quarterly reports, and compliance certification), and 97.635 (petitions for alternatives to monitoring, recordkeeping, or reporting requirements).
- 2. The emissions data determined in accordance with 40 CFR 97.630 through 97.635 shall be used to calculate allocations of TR SO₂ Group 1 allowances under 40 CFR 97.611(a)(2) and (b) and 97.612 and to determine compliance with the TR SO₂ Group 1 emissions limitation and assurance provisions under paragraph (c) below, provided that, for each monitoring location from which mass emissions are reported, the mass emissions amount used in calculating such allocations and determining such compliance shall be the mass emissions amount for the monitoring location determined in accordance with 40 CFR 97.630 through 97.635 and rounded to the nearest ton, with any fraction of a ton less than 0.50 being deemed to be zero.

c. SO₂ emissions requirements.

- 1. TR SO₂ Group 1 emissions limitation.
- i. As of the allowance transfer deadline for a control period in a given year, the owners and operators of each TR SO₂ Group 1 source and each TR SO₂ Group 1 unit at the source shall hold, in the source's compliance account, TR SO₂ Group 1 allowances available for deduction for such control period under 40 CFR 97.624(a) in an amount not less than the tons of total SO₂ emissions for such control period from all TR SO₂ Group 1 units at the source.
- ii. If total SO₂ emissions during a control period in a given year from the TR SO₂ Group 1 units at a TR SO₂ Group 1 source are in excess of the TR SO₂ Group 1 emissions limitation set forth in paragraph (c)(1)(i) above, then:
 - A. The owners and operators of the source and each TR SO₂ Group 1 unit at the source shall hold the TR SO₂ Group 1 allowances required for deduction under 40 CFR 97.624(d); and
 - B. The owners and operators of the source and each TR SO₂ Group 1 unit at the source shall pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act, and each ton of such excess emissions and each day of such control period shall constitute a separate violation 40 CFR part 97, subpart CCCCC and the Clean Air Act.
 - 2. TR SO₂ Group 1 assurance provisions.
 - If total SO₂ emissions during a control period in a given year from all TR SO₂ Group 1 units at TR SO₂ Group 1 sources in the state exceed the state assurance level, then the owners and operators of such sources and units in each group of one or more sources and units having a common designated representative for such control period, where the common designated representative's share of such SO₂ emissions during such control period exceeds the common

designated representative's assurance level for the state and such control period, shall hold (in the assurance account established for the owners and operators of such group) TR SO₂ Group 1 allowances available for deduction for such control period under 40 CFR 97.625(a) in an amount equal to two times the product (rounded to the nearest whole number), as determined by the Administrator in accordance with 40 CFR 97.625(b), of multiplying—

- The quotient of the amount by which the common designated representative's share of such SO₂ emissions exceeds the common designated representative's assurance level divided by the sum of the amounts, determined for all common designated representatives for such sources and units in the state for such control period, by which each common designated representative's share of such SO₂ emissions exceeds the respective common designated representative's assurance level; and
- A. The amount by which total SO₂ emissions from all TR SO₂ Group 1 units at TR SO₂ Group 1 sources in the state for such control period exceed the state assurance level.
- i. The owners and operators shall hold the TR SO₂ Group 1 allowances required under paragraph (c)(2)(i) above, as of midnight of November 1 (if it is a business day), or midnight of the first business day thereafter (if November 1 is not a business day), immediately after such control period.
- ii. Total SO₂ emissions from all TR SO₂ Group 1 units at TR SO₂ Group 1 sources in the state during a control period in a given year exceed the state assurance level if such total SO₂ emissions exceed the sum, for such control period, of the state SO₂ Group 1 trading budget under 40 CFR 97.610(a) and the state's variability limit under 40 CFR 97.610(b).
- iii. It shall not be a violation of 40 CFR part 97, subpart CCCCC or of the Clean Air Act if total SO₂ emissions from all TR SO₂ Group 1 units at TR SO₂ Group 1 sources in the state during a control period exceed the state assurance level or if a common designated representative's share of total SO₂ emissions from the TR SO₂ Group 1 units at TR SO₂ Group 1 sources in the state during a control period exceeds the common designated representative's assurance level.
- iv. To the extent the owners and operators fail to hold TR SO₂ Group 1 allowances for a control period in a given year in accordance with paragraphs (c)(2)(i) through (iii) above,
 - . The owners and operators shall pay any fine, penalty, or assessment or comply with any other remedy imposed under the Clean Air Act; and
 - A. Each TR SO₂ Group 1 allowance that the owners and operators fail to hold for such control period in accordance with paragraphs (c)(2)(i) through (iii) above and each day of such control period shall constitute a separate violation of 40 CFR part 97, subpart CCCCC and the Clean Air Act.
 - 3. Compliance periods.
 - . A TR SO₂ Group 1 unit shall be subject to the requirements under paragraph (c)(1) above for the control period starting on the later of January 1, 2015 or the deadline for meeting the unit's monitor certification requirements under 40 CFR 97.630(b) and for each control period thereafter.
- i. A TR SO₂ Group 1 unit shall be subject to the requirements under paragraph (c)(2) above for the control period starting on the later of January 1, 2017 or the deadline for meeting the unit's monitor certification requirements under 40 CFR 97.630(b) and for each control period thereafter.
 - 4. Vintage of allowances held for compliance.

- . A TR SO₂ Group 1 allowance held for compliance with the requirements under paragraph (c)(1)(i) above for a control period in a given year must be a TR SO₂ Group 1 allowance that was allocated for such control period or a control period in a prior year.
- i. A TR SO₂ Group 1 allowance held for compliance with the requirements under paragraphs (c)(1)(ii)(A) and (2)(i) through (iii) above for a control period in a given year must be a TR SO₂ Group 1 allowance that was allocated for a control period in a prior year or the control period in the given year or in the immediately following year.
 - 5. Allowance Management System requirements. Each TR SO₂ Group 1 allowance shall be held in, deducted from, or transferred into, out of, or between Allowance Management System accounts in accordance with 40 CFR part 97, subpart CCCCC.
 - 6. Limited authorization. A TR SO₂ Group 1 allowance is a limited authorization to emit one ton of SO₂ during the control period in one year. Such authorization is limited in its use and duration as follows:
- . Such authorization shall only be used in accordance with the TR SO_2 Group 1 Trading Program; and
- i. Notwithstanding any other provision of 40 CFR part 97, subpart CCCCC, the Administrator has the authority to terminate or limit the use and duration of such authorization to the extent the Administrator determines is necessary or appropriate to implement any provision of the Clean Air Act.
 - 7. Property right. A TR SO₂Group 1 allowance does not constitute a property right.

d. Title V permit revision requirements.

- 1. No title V permit revision shall be required for any allocation, holding, deduction, or transfer of TR SO₂ Group 1 allowances in accordance with 40 CFR part 97, subpart CCCCC.
- 2. This permit incorporates the TR emissions monitoring, recordkeeping and reporting requirements pursuant to 40 CFR 97.630 through 97.635, and the requirements for a continuous emission monitoring system (pursuant to 40 CFR part 75, subparts B and H), an excepted monitoring system (pursuant to 40 CFR part 75, appendices D and E), a low mass emissions excepted monitoring methodology (pursuant to 40 CFR part 75.19), and an alternative monitoring system (pursuant to 40 CFR part 75, subpart E), Therefore, the Description of TR Monitoring Provisions table for units identified in this permit may be added to, or changed, in this title V permit using minor permit modification procedures in accordance with 40 CFR 97.606(d)(2) and 70.7(e)(2)(i)(B) or 71.7(e)(1)(i)(B).

e. Additional recordkeeping and reporting requirements.

- 1. Unless otherwise provided, the owners and operators of each TR SO₂ Group 1 source and each TR SO₂ Group 1 unit at the source shall keep on site at the source each of the following documents (in hardcopy or electronic format) for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the Administrator.
- i. The certificate of representation under 40 CFR 97.616 for the designated representative for the source and each TR SO₂ Group 1 unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such certificate of representation and documents are superseded because of the submission of a new certificate of representation under 40 CFR 97.616 changing the designated representative.

- ii. All emissions monitoring information, in accordance with 40 CFR part 97, subpart CCCCC.
- iii. Copies of all reports, compliance certifications, and other submissions and all records made or required under, or to demonstrate compliance with the requirements of, the TR SO₂ Group 1 Trading Program.
 - 2. The designated representative of a TR SO₂ Group 1 source and each TR SO₂ Group 1 unit at the source shall make all submissions required under the TR SO₂ Group 1 Trading Program, except as provided in 40 CFR 97.618. This requirement does not change, create an exemption from, or otherwise affect the responsible official submission requirements under a title V operating permit program in 40 CFR parts 70 and 71.

f. Liability.

- 1. Any provision of the TR SO₂ Group 1 Trading Program that applies to a TR SO₂ Group 1 source or the designated representative of a TR SO₂ Group 1 source shall also apply to the owners and operators of such source and of the TR SO₂ Group 1 units at the source.
- 2. Any provision of the TR SO₂ Group 1 Trading Program that applies to a TR SO₂ Group 1 unit or the designated representative of a TR SO₂ Group 1 unit shall also apply to the owners and operators of such unit.

g. Effect on other authorities.

No provision of the TR SO₂ Group 1 Trading Program or exemption under 40 CFR 97.605 shall be construed as exempting or excluding the owners and operators, and the designated representative, of a TR SO₂ Group 1 source or TR SO₂ Group 1 unit from compliance with any other provision of the applicable, approved state implementation plan, a federally enforceable permit, or the Clean Air Act.